



**Types CLE-1 and CLE-2 Current Limiting Power Fuses**  
Total clearing time-current characteristics, 14.4 Kv

Curves are based on tests starting with fuse units at an ambient temperature of 25°C and without initial load. Curves are plotted to maximum test points so variations should be negative.

**Westinghouse Electric Corporation**  
Switchgear Division, Power Switching Equipment, East Pittsburgh, Pa.  
Printed in USA

Curve No.

**35**

Supersedes Curve No. 35, dated November, 1966

Reference No. 598784

May, 1968