



Westinghouse Electric Corporation
Relay-Instrument Division
Coral Springs, FL 33065

Renewal Parts Data
41-107

Page 1

March, 1984
Supersedes RPD 41-107
Pages 1-2, dated November, 1983
Mailed to: E, D, C/41-400B

In FT-21 Flexitest Cases

Type CGRS Ratio Ground Relay

Type CGRS Relay in FT-21 Case^①

Complete Relay Style Number	Amp. Rating	I.C.S. Range, Amps.	Contact Arrange- ment	Style Number of Parts			
				Electro- magnet (front)	Disc and Shaft Assembly	Moving Contact Spring and Adjuster	I.C.S. Unit ^② (Top left)
1345D81A01	10	0.2-2.0	SPST	1484B92G10	880A772G16	880A721G11	3491A34G40

Description of Part	Style Number
Permanent Magnet	52D6283G03
Electromagnet - Back - Restraint	1484B92G11
Tap Screw (5 used)	1545 282
Electromagnet - Front - Operating	See Table
Top Bearing Screw	52D6291G03
Moving Contact, Spring and Adjuster Assembly	See Table
Disc and Shaft Assembly	See Table
Top Bearing	1210 530
Bottom Bearing	184A440G01
Bottom Bearing Screw	3499A37G09
Locknut for Bottom Bearing Screw	203 056
Stationary Contact Block Assembly	406C992G05
Stationary Contact on Spring	1732 776
Card Holder Clip	182A798H01
I.C.S. Unit	See Table ^②
Stationary Contacts for I.C.S. Unit (2 used)	1732 868

Parts indented are included in the part under which they are indented.

① For flexitest case parts, refer to RPD 41-076A1.

② For ICS unit parts, refer to RPD 41-852A1.

Ordering Information

- Give style number and name of part.
- Give the complete nameplate reading.
- State method of shipment desired.
- Send all orders or correspondence to nearest sales office of the company.

