


INSTRUCTION MANUAL

FOR

OVERCURRENT RELAY

BE1-50/51B



Basler Electric

Publication: 9252000991
Revision: N 03/08

www.ElectricalPartManuals.com

INTRODUCTION

This instruction manual provides information about the operation and installation of the BE1-50/51B Overcurrent Relay. To accomplish this, the following information is provided:

- General Information and Specifications
- Controls and Indicators
- Functional Description
- Installation and Maintenance
- Testing

WARNING!

To avoid personal injury or equipment damage, only qualified personnel should perform the procedures in this manual.

NOTE

Be sure that the relay is hard-wired to earth ground with no smaller than 12 AWG copper wire attached to the ground terminal on the rear of the unit case. When the relay is configured in a system with other devices, it is recommended to use a separate lead to the ground bus from each unit.

First Printing: April 1992

Printed in USA

© 2008 Basler Electric, Highland Illinois 62249 USA

All Rights Reserved

March 2008

CONFIDENTIAL INFORMATION

of Basler Electric, Highland Illinois, USA. It is loaned for confidential use, subject to return on request, and with the mutual understanding that it will not be used in any manner detrimental to the interest of Basler Electric.

It is not the intention of this manual to cover all details and variations in equipment, nor does this manual provide data for every possible contingency regarding installation or operation. The availability and design of all features and options are subject to modification without notice. Should further information be required, contact Basler Electric.

**BASLER ELECTRIC
ROUTE 143, BOX 269
HIGHLAND IL 62249 USA**

<http://www.basler.com>, info@basler.com

PHONE +1 618.654.2341

FAX +1 618.654.2351

REVISION HISTORY

The following information provides a historical summary of the changes made to this instruction manual (9252000991). Revisions are listed in reverse chronological order.

Manual Revision and Date	Change
N, 03/08	<ul style="list-style-type: none"> Updated front panel drawings to show new target reset button. Added GOST-R to Section 1. Moved content of Section 7, <i>Manual Change Information</i>, to manual <i>Introduction</i>. Moved Characteristic Curve graphs from Section 1 to new Appendix A. Moved content of Section 6, <i>Maintenance</i>, into Section 4, <i>Installation</i>.
M, 11/00	<ul style="list-style-type: none"> Updated drawings in Section 2 to reflect changes to the PC board. Updated the manual to reflect the change in switch call out from SW8 to SW3. Added new functionality to the PICKUP LED. It is now the ACTIVE/PICKUP LED and will be green when active and red when picked up.
L, 12/99	<ul style="list-style-type: none"> Changed all drawings to show the newly designed front cover. Changed all references to the current for testing the targets to an ac only type of current.
K, 02/99	<ul style="list-style-type: none"> Page 2-2: added description to Locator K for 100 series relays, unit revision Q and previous. Deleted Figure 2-2 from Section 2 and added it to new Section 8. Page 3-2: added description to <i>Auxiliary Output Contacts</i> for 100 series relays, unit revision R and subsequent. Added new Section 8, <i>Relay Differences</i>.
J, 05/98	<ul style="list-style-type: none"> Added Patent Number to <i>Specifications</i> and changed the manual format to reflect current manual styles.
I, 07/97	<ul style="list-style-type: none"> Added Model # BE1-50/51B-203 to Table 1-1. Corrected Tables 1-3 and 1-4, <i>Figure Number</i>. Changed "pickup setting" to "pickup" on pages 1-7, <i>Time Characteristics equation</i>, page 1-9, <i>Time Reset</i>, and Figures 1-6 through 1-14. Added Oscillatory to <i>Surge Withstand Capability</i> on page 1-11. Corrected Figure 1-18 to reflect the correct Time Dial range: 0.5 to 9.9. Changed Table 7-1 to add ECA and date data.
H, 02/96	<ul style="list-style-type: none"> Incorporated changed in series 200 relays that added five characteristic curves and changed switch SW8-3 functionality. Changed Section 5, <i>Testing</i>, to incorporate setting all sections of switch SW8.
G, 10/95	<ul style="list-style-type: none"> Corrected minor typographical errors in Section 1 and 2. Corrected Table 2-1, locator item K, <i>Function</i>. Changed Figure 5-2 and all testing target current source references from 0.2 ampere to 1.0 ampere. Changed Table 7-1 to add ECA and date data.
F, 02/95	<ul style="list-style-type: none"> Changed all sections to reflect 200 series relay additions and relay modifications that deleted P2 and P3 jumpers and added switch SW8. Changed <i>Specifications</i>, TIME and ISNT PICKUP accuracy; Output Circuits, and Isolation (Dielectric Test).
E, 09/94	<ul style="list-style-type: none"> Corrected Figure 4-8.

D, 05/94	<ul style="list-style-type: none"> • Clarified TIME PICKUP and INST PICKUP specification ranges, page 1-3. • Changed Figure 1-2 to also show one ampere unit burden data. • Changed time characteristics accuracy statement, page 1-6. • Added (repeated) equation for the characteristic curve time functions, page 1-8. • Changed Figure 1-4 to show one ampere unit starting data. • Separated Section 4, <i>Installation</i>, into Section 4, <i>Installation</i>, and Section 5, <i>Testing</i>, and bumped all subsequent sections.
C, 06/93	<ul style="list-style-type: none"> • Added column for CT secondary to Table 1-1 and UL Recognition and CSA Certification to specifications. • Page 3-2: Deleted “or reset” from last sentence in paragraph <i>Outputs</i>. Changed from “The targets will not operate or reset...” to “The targets will not operate...” • Page 4-1: Corrected dielectric test leakage current per terminal.
B, 09/92	<ul style="list-style-type: none"> • Page 1-1: Application, deleted reference to dust tight cover. • Page 1-3: Specifications, TIME Dropout to not less than 95% of pickup value. • Page 1-6: Specifications, Time Reset, added statement to insure sufficient power to power-up relay when using decaying characteristic. • Page 1-7: Specifications, corrected Storage Range Temperature degrees F. • Page 1-8: Defined British Standard curve types. • Page 2-1: INST and TIME PICKUP selectors, added statement that changing selectors while relay is in service may cause tripping. • Page 4-4: Changed Figures 4-4 and 4-5. • Page 4-6: Changed Figure 4-8. • Page 4-9: Time Pickup Test, Step 1, changed 0.45 A to 0.485 A. • Page 4-11: Time Pickup Test, Step 1, changed 0.09 A to 0.096 A. • Page 4-13: Added paragraph SETTING THE RELAY. • Added Section 6.
A, 05/92	<ul style="list-style-type: none"> • Changed manual title to BE1-50/51B and incorporated engineering changes accordingly.
—, 04/92	<ul style="list-style-type: none"> • Initial release.

CONTENTS

SECTION 1 • GENERAL INFORMATION	1-1
SECTION 2 • CONTROLS AND INDICATORS	2-1
SECTION 3 • FUNCTIONAL DESCRIPTION	3-1
SECTION 4 • INSTALLATION	4-1
SECTION 5 • TESTING	5-1
SECTION 6 • RELAY DIFFERENCES	6-1
APPENDIX A • TIME CHARACTERISTIC CURVES	A-1

This page intentionally left blank.

SECTION 1 • GENERAL INFORMATION

TABLE OF CONTENTS

SECTION 1 • GENERAL INFORMATION	1-1
INTRODUCTION.....	1-1
FEATURES.....	1-1
Advantages.....	1-1
MODEL NUMBERS	1-2
SPECIFICATIONS	1-4
Current Sensing Input	1-4
Time Overcurrent (51) Element.....	1-4
Instantaneous Overcurrent (50) Element	1-6
Burden	1-8
Frequency Response	1-8
Transient Response	1-8
Harmonic Response.....	1-8
Target Indicators	1-9
Output Contacts	1-9
AUX Output Contact.....	1-9
Type Tests.....	1-9
Environment	1-10
Agency Recognition	1-10
Patent	1-10
Physical	1-10

Figures

Figure 1-1. BE1-50/51B, S1 Case	1-2
Figure 1-2. Integrating Reset Characteristic Curve	1-6
Figure 1-3. Instantaneous Characteristic Curves	1-7
Figure 1-4. Burden Characteristics.....	1-8
Figure 1-5. Harmonic Rejection.....	1-9

Tables

Table 1-1. BE1-50/51B Overcurrent Relays, One Ampere CT Secondary, 50/60 Hz.....	1-3
Table 1-2. BE1-50/51B Overcurrent Relays, Five Ampere CT Secondary, 50/60 Hz.....	1-3
Table 1-3. Time Characteristic Curve Constants with SW3-3 Open (Off) (Series 100 Relays or Series 200 Relays).....	1-5
Table 1-4. Time Characteristic Curve Constants with SW3-3 Closed (On) (Series 200 Relays)	1-5

This page intentionally left blank.

SECTION 1 • GENERAL INFORMATION

INTRODUCTION

BE1-50/51B overcurrent relays are microprocessor based, non-directional phase or ground relays that monitor the magnitude of a single phase ac current to provide accurate instantaneous and time overcurrent protection for 50 or 60 Hz power systems. Models are available with fifteen popular time characteristics and a wide range of pickup settings.

FEATURES

A wide range of pickup settings and front panel selectable time characteristics permit applications involving coordination with fuses, reclosers, cold load pickup, motor starting, and fixed time requirements. Also, an integrating reset function is available to simulate the disk reset of electromechanical relays.

BE1-50/51B overcurrent relays have the following standard features.


- Independent time and instantaneous elements
- A secure method to manually trip the breaker at the relay front panel
- Direct reading front panel controls
- Minimum pickup setting for safety during installation
- Time characteristics extend to a pickup multiple of 40
- Rugged draw-out construction with steel case
- Gravity latching targets retain indication without power
- Built-in accuracy eliminates internal adjustments
- Minimum transient overreach
- Field selectable characteristic curve selection
- Field selectable instantaneous or integrating reset
- Field selectable 50 or 60 Hz operation
- Field selectable fixed instantaneous delay (0.0, 0.1, 0.2, or 0.3 second on 100 series relays and 0.0 or 0.1 second on 200 series relays.).

Individual models are available for 1 ampere and 5 amperes sensing input currents and installed in A1 or S1 cases. BE1-50/51B overcurrent relays may be tested without removing the relay from the case. Shorting contacts are provided for all current inputs when the connection plug or relay chassis is removed from the relay case. Figure 1-1 shows the front panel of the BE1-50/51B overcurrent relay, in an S1 case.

Advantages

BE1-50/51B overcurrent relays have many advantages over other overcurrent relays. The primary advantages are:

- Time characteristics are defined by equations and graphs
- Field selectable time characteristics
- Very low burden extends the linear range of the CTs
- Self powered from the sensed current
- Continuous automatic calibration



P0052-86

Figure 1-1. BE1-50/51B, S1 Case

MODEL NUMBERS

Model number variations in the BE1-50/51B overcurrent relays are specified by a three digit extension to the model number. Tables 1-1 and 1-2 provide model number, case style, switch SW3-3 selections, and sensing current input ranges. Internal switches provide for selecting system operating frequencies of 50 or 60 Hz, instantaneous element delays, curve sets, and instantaneous or integrating reset characteristics. The location and description of these switches is provided in Section 2. Integrating reset is available in 100 series relays (e.g. - BE1-50/51B-105) when there is adequate input current to power the relay. Integrating reset is available in 200 series relays (e.g. - BE1-50/51B-205) even when the input current falls to zero. Two-hundred series relays also have additional characteristic curves available through curve set selection.

Table 1-1. BE1-50/51B Overcurrent Relays, One Ampere CT Secondary, 50/60 Hz

Model Number	Case Style	SW3-3 Selects	Sensing Input Range (Amps)	
			TIME	INST
BE1-50/51B-101	A1	0.2 Second Delay	0.1 - 3.18	0.2 - 19.8
BE1-50/51B-201	A1	Curve Set	0.1 - 3.18	0.2 - 19.8
BE1-50/51B-102	S1 (Projection Mount)	0.2 Second Delay	0.1 - 3.18	0.2 - 19.8
BE1-50/51B-202	S1 (Projection Mount)	Curve Set	0.1 - 3.18	0.2 - 19.8
BE1-50/51B-103	S1 (Semi-Flush Mount)	0.2 Second Delay	0.1 - 3.18	0.2 - 19.8
BE1-50/51B-203	S1 (Semi-Flush Mount)	Curve Set	0.1 - 3.18	0.2 - 19.8

Table 1-2. BE1-50/51B Overcurrent Relays, Five Ampere CT Secondary, 50/60 Hz

Model Number	Case Style	SW3-3 Selects	Sensing Input Range (Amps)	
			TIME	INST
BE1-50/51B-105	A1	0.2 Second Delay	0.5 - 15.9	1.0 - 99.0
BE1-50/51B-205	A1	Curve Set	0.5 - 15.9	1.0 - 99.0
BE1-50/51B-106	S1 (Projection Mount)	0.2 Second Delay	0.5 - 15.9	1.0 - 99.0
BE1-50/51B-206	S1 (Projection Mount)	Curve Set	0.5 - 15.9	1.0 - 99.0
BE1-50/51B-107	S1 (Semi-Flush Mount)	0.2 Second Delay	0.5 - 15.9	1.0 - 99.0
BE1-50/51B-207	S1 (Semi-Flush Mount)	Curve Set	0.5 - 15.9	1.0 - 99.0

NOTE: 100 series relays (e.g. - BE1-50/51B-105) have the integrating reset function when there is adequate input current to power the relay. 200 series relays (e.g. - BE1-50/51B-205) have the integrating reset function even when the input current falls to zero.

SPECIFICATIONS

BE1-50/51B electrical and physical specifications are listed in the following paragraphs.

Current Sensing Input

1 Ampere Unit

Continuous Current: 2.8 Aac
One Second Rating: 80 Aac

5 Ampere Unit

Continuous Current: 14 Aac
One Second Rating: 400 Aac

Time Overcurrent (51) Element

Setting the TIME PICKUP control at the minimum pickup setting (0.1 on the 1 ampere unit and 0.5 on the 5 ampere unit), places the relay in the most sensitive state and may be used as a safety setting.

1 Ampere Unit Pickup

Setting Range: 0.1 to 3.18 Aac
Setting Increment: 0.02 Aac
Accuracy: $\pm 2\%$, ± 5 milliamperes at or above 0.1 ampere setting

5 Ampere Unit Pickup

Setting Range: 0.5 to 15.9 Aac
Setting Increment: 0.1 Aac
Accuracy: $\pm 2\%$, ± 25 milliamperes at or above 0.5 ampere setting

Dropout

Dropout occurs at 95% of pickup value.

Timing Range

0.0 to 9.9 seconds in 0.1 second steps.

Timing Accuracy

The timing accuracy is the sum of ± 1 cycle, $\pm 2\%$. This accuracy applies to the range of 1.3 to 40 times tap and is for a given measured multiple of tap. The measurement of the multiple of tap has an accuracy that is the sum of $\pm 2\%$, ± 25 milliamperes for 5 ampere units, and $\pm 2\%$, ± 5 milliamperes for 1 ampere units.

Timing Accuracy Example (5 Ampere Unit)

PU setting: 5 amperes
Current Applied: 6.5 amperes
+ Multiple Tolerance: 6.655 amperes
– Multiple Tolerance: 6.345 amperes
Time Curve: E
Time Dial: 5.0
Minimum time dial
using 6.655 amperes: 46.5470 seconds
Maximum time dial
using 6.345 amperes: 61.3968 seconds
Curve time using 6.5 amperes: 53.1800 seconds

Curve Characteristics

Nine inverse time functions and one fixed time function can be selected by the front-panel Curve switch. Characteristic curves for the inverse and definite time functions are defined by the following equation.

$$T_T = \frac{AD}{M^N - C} + BD + K$$

Where: T_T = time to trip in seconds
 D = time dial setting
 M = multiple of pickup setting
 A, B, C, N, K = constants for the particular curve

Time characteristic curve constants are listed in Tables 1-3 and 1-4. Constants have been selected to conform to the characteristics of electromechanical relays over a range of pickup multiples from 1.3 to 40. Values of the constants are provided for use in computer relay setting software. Timing accuracy is ± 1 cycle, ± 2 percent of time to trip.

*Table 1-3. Time Characteristic Curve Constants with SW3-3 Open (Off)
(Series 100 Relays or Series 200 Relays)*

Curve Type *		Figure Number †	Constants					
BE1	Similar To		A	B	C	N	K	R
S	ABB CO-2	A-1	0.2663	0.03393	1.000	1.2969	0.028	0.500
L	ABB CO-5	A-2	5.6143	2.18592	1.000	1.000	0.028	15.750
D	ABB CO-6	A-3	0.4797	0.21359	1.000	1.5625	0.028	0.875
M	ABB CO-7	A-4	0.3022	0.12840	1.000	0.5000	0.028	1.750
I	ABB CO-8	A-5	8.9341	0.17966	1.000	2.0938	0.028	9.000
V	ABB CO-9	A-6	5.4678	0.10814	1.000	2.0469	0.028	5.500
E	ABB CO-11	A-7	7.7624	0.02758	1.000	2.0938	0.028	7.750
B	BS142-B ‡	A-8	1.4638	0.00000	1.000	1.0469	0.028	3.250
C	BS142-C ‡	A-9	8.2506	0.00000	1.000	2.0469	0.028	8.000
F	None §	N/A	0.0000	1.00000	0.000	0.0000	0.000	1.000

*Table 1-4. Time Characteristic Curve Constants with SW3-3 Closed (On)
(Series 200 Relays)*

Curve Type *		Figure Number †	Constants					
BE1	Similar To		A	B	C	N	K	R
S	GE IAC 55	A-10	0.0286	0.0208	1.000	0.9844	0.028	0.0940
L	GE IAC 66	A-11	2.3955	0.00002	1.000	0.3125	0.028	7.8001
D	ABB CO-6	A-3	0.4797	0.21359	1.000	1.5625	0.028	0.8750
M	ABB CO-7	A-4	0.3022	0.12840	1.000	0.5000	0.028	1.7500
I	GE IAC 51	A-12	0.2747	0.1042	1.000	0.4375	0.028	0.8868
V	GE IAC 53	A-13	4.4309	0.0991	1.000	1.9531	0.028	5.8231
E	GE IAC 77	A-14	4.9883	0.0129	1.000	2.0469	0.028	4.7742
B	BS142-B ‡	A-8	1.4636	0.00000	1.000	1.0469	0.028	3.2500
C	BS142-C ‡	A-9	8.2506	0.00000	1.000	2.0469	0.028	8.0000
F	None §	N/A	0.0000	1.00000	0.000	0.0000	0.000	1.0000

Notes for Tables 1-2 and 1-3

* BE1 Curve Types:

S: Short Inverse
L: Long Inverse
D: Definite Time
M: Moderately Inverse
I: Inverse

V: Very Inverse
E: Extremely Inverse
B: BS142 Very Inverse
C: BS142 Extremely Inverse
F: Fixed Time Delay

† Figure numbers refer to the characteristic curves located in Appendix A, *Time Characteristic Curves*.

‡ Curves B and C are defined in British Standard BS142 and IEC Standard IEC 255-4.

§ Fixed time delay, adjustable from 0.1 to 9.9 seconds.

Integrating Reset

Reset begins when the current drops below 95% of pickup and the relay has not timed out. Switch SW3-4 provides selection of either an instantaneous or integrating reset characteristic. Opening SW3-4 forces the instantaneous reset timer to zero when timed dropout occurs. This fast reset characteristic prevents the ratcheting effect that may occur with repeating system faults. Closing SW3-4 selects the integrating reset characteristic. The integrating reset characteristic simulates the disk reset of electromechanical relays. When the integrating reset characteristic is selected on 100 series relays, insure that sufficient input power is available to power up the relay. This is not required on Series 200 relays. Series 200 relays provide the integrating reset function even when input current falls to zero.

Integrating reset characteristics are defined by the following equation and shown in Figure 1-2. Equation constants are provided in Tables 1-3 or 1-4.

Integrating Reset Equation:

$$T_R = \frac{RD}{M^2 - 1}$$


Where:

T_R = Time to reset in seconds

R = Constant for the particular curve

D = TIME DIAL setting

M = Current in multiples of PICKUP setting during reset



Vertical axis xRD (Seconds) is applicable for all curves and is derived from multiplying the constant R for the curve selected times D (the Time Dial setting).

Figure 1-2. Integrating Reset Characteristic Curve

Instantaneous Overcurrent (50) Element

Setting the INST PICKUP control to the minimum pickup setting (0.2 on the 1 ampere unit and 1.0 on the 5 ampere unit), places the relay in the most sensitive state and may be used as a safety setting.

1 Ampere Unit Pickup

Setting Range: 0.2 to 19.8 Aac

Setting Increment: 0.2 Aac

Accuracy: $\pm 2\%$, ± 5 milliamperes at or above 0.2 ampere setting

5 Ampere Unit Pickup

Setting Range: 1 to 99 Aac
Setting Increment: 1 Aac
Accuracy: $\pm 2\%$, ± 25 milliamperes at or above 1.0 ampere setting

Dropout

Dropout occurs at 95% of pickup value.

Curve Characteristics

BE1-50/51B instantaneous characteristic curves are similar to standard electromechanical instantaneous units. However, the time to trip for ground applications is slightly longer than that for phase applications to allow time to power up the relay. Longer trip time for ground applications is beneficial because it helps to avoid nuisance trips.

For phase applications, the maximum time to trip is 3.5 cycles at a pickup multiple of 1.0, and 1.5 cycles at a pickup multiple of 3.0. The corresponding times for ground applications are 4.5 and 1.75 cycles. Figure 1-3 shows the instantaneous characteristic curves for maximum time to trip.

On 100 series relays, additional delays of 0.1, 0.2, or 0.3 seconds may be added with internal switches SW3-2 and SW3-3. These delays apply to both phase and ground applications. Closing switch SW3-2 provides an additional delay of 0.1 second. Closing switch SW3-3 provides an additional delay of 0.2 second. Closing both switches SW3-2 and SW3-3 provides an additional delay of 0.3 second. Section 2 illustrates the location of SW3.

On 200 series relays, an additional delay of 0.1 second may be added with internal switch SW3-2. This delay applies to both phase and ground applications. Closing switch SW3-2 provides the additional delay of 0.1 second.




Figure 1-3. Instantaneous Characteristic Curves

Burden

Burden is non-linear. Figure 1-4 illustrates the device burden.

1 Ampere Unit

0.1 amperes: $Z = 120 \Omega$

1.0 ampere: $Z = 5 \Omega$

5 Ampere Unit

0.5 amperes: $Z = 4.8 \Omega$

5.0 amperes: $Z = 0.2 \Omega$




Figure 1-4. Burden Characteristics

Frequency Response

A change of ± 5 Hz from the nominal 50/60 Hz current causes $<0.5\%$ change in the current required for pickup.

Transient Response

$<10\%$ overreach with system time constants up to 40 ms.

Harmonic Response

Figure 1-5 shows that a relay set for 1 ampere pickup would pick up at 0.96 amperes with a current containing 40% seventh harmonic. This corresponds to a 10:1 rejection ratio. Other conditions may be evaluated in the same manner.




Figure 1-5. Harmonic Rejection

Target Indicators

Gravity latched, manually reset targets indicate that current of 0.2 amperes or greater was present in the trip circuit. Target coil resistance is less than 0.1 ohms and operate time is less than one millisecond. See *Output Contacts* for maximum current rating.

Output Contacts

Output contacts are surge protected and rated as follows:

Resistive Ratings

120/240 Vac: Make 30 amperes for 0.2 seconds, carry 7 amperes for 2 minutes, 3 amperes continuously, and break 5 amperes.

125/250 Vdc: Make 30 amperes for 0.2 seconds, carry 7 amperes for 2 minutes, 3 amperes continuously, and break 0.3 ampere.

Inductive Ratings

120/240 Vac, 125/250 Vdc: Make and carry 30 amperes for 0.2 seconds, carry 7 amperes for 2 minutes, 3 amperes continuously, and break 0.3 ampere. (L/R = 0.04).

AUX Output Contact

The AUX Output contact can be configured in the field using jumpers to select closing on either timed or instantaneous trip. The AUX output contact is surge protected and has the same ratings as the output contacts above.

Type Tests

Isolation

Meets IEC 255-5 and exceeds IEEE C37.90-1989, one-minute dielectric (high potential) tests as follows:

All circuits to ground: 2,828 Vdc
Input to Output Circuits: 2,000 Vac or 2,828 Vdc

Surge Withstand Capability

Qualified to IEEE C37.90.1-1989 *Standard Surge Withstand Capability (SWC) Tests for Protective Relays and Relay Systems*.

Impulse

Qualified to IEC 255-5.

Radio Frequency Interference (RFI)

Field-tested using a 5-watt, hand-held transceiver operating at random frequencies centered around 144 MHz and 440 MHz, with the antenna located 6 inches from the relay in both horizontal and vertical planes.

Vibration

Withstands 2 G in each of three mutually perpendicular planes swept over the range of 10 to 500 Hz for a total of 6 sweeps, 15 minutes each sweep.

Shock

Withstands 15 G in each of three mutually perpendicular planes.

Environment

Operating Temperature: -40°C to 70°C (-40°F to 158°F)

Storage Temperature: -50°C to 70°C (-58°F to 158°F).

Agency Recognition

UL Recognized/CSA Certified

UL Recognized per Standard 508, UL File No. E97033. CSA Certified per Standard CAN/CSA-C22.2 No. 14-M91, CSA File No. LR 23131.

Note: Output contacts are not UL Recognized/CSA Certified for voltages greater than 250 volts.

GOST-R Certification

GOST-R certified No. POCC US.ME05.B03391; complies with the relevant standards of Gosstandart of Russia. Issued by accredited certification body POCC RU.0001.11ME05.

Patent

Patented in U.S., 1998, U.S. Patent No. 5751532.

Physical

Weight: 8.6 lb (3.9 kg)

SECTION 2 • CONTROLS AND INDICATORS

TABLE OF CONTENTS

SECTION 2 • CONTROLS AND INDICATORS	2-1
INTRODUCTION.....	2-1
Figures	
Figure 2-1. Location of Controls and Indicators	2-1
Figure 2-2. Location of SW3 and Auxiliary Output Jumper Terminations	2-2
Tables	
Table 2-1. BE1-50/51B Controls and Indicators (Refer to Figures 2-1 and 2-2)	2-3

This page intentionally left blank.

SECTION 2 • CONTROLS AND INDICATORS

INTRODUCTION

Figure 2-1 illustrates the front panel controls and indicators of the BE1-50/51B. Figure 2-2 illustrates the location of switch SW3. Both illustrations have lettered call-outs that correspond to the control and indicator descriptions provided in Table 2-1.




Figure 2-1. Location of Controls and Indicators



Table 2-1. BE1-50/51B Controls and Indicators (Refer to Figures 2-1 and 2-2)

Locator	Control or Indicator	Function
A	INST MANUAL TRIP Test Points	When shorted, the test points (jacks) provide a secure means to manually trip the controlled breaker. Jacks accept a standard 0.08 inch diameter phone tip plug.
B	INST PICKUP Selectors	Two switches (TENS and UNITS on five ampere models, COARSE and FINE on one ampere models) to select pickup current in amperes. Changing switch selectors while the relay is in service may cause tripping.
C	Targets	Red target indicators latch when the trip circuit current is greater than 0.2 amperes. One target each for TIME and INST.
D	TIME PICKUP Selectors	Two switches (TENS and UNITS on five ampere models, COARSE and FINE on one ampere models) to select pickup current in amperes. Changing switch selectors while the relay is in service may cause tripping.
E	CURVE Selector	Ten position selector switch to select one of nine inverse functions or one fixed time function.
F	TIME DIAL Selectors	Two selector switches (UNITS and TENTHS) to select the desired characteristic curve. A setting of 0.0 results in instantaneous operation without any intentional delay. A setting of 9.9 corresponds to the typical time provided by an electromechanical relay at its maximum dial setting.
G	TIME MANUAL TRIP Test Points	When shorted, the test points provide a secure means to manually trip the controlled breaker. Jacks accept a standard 0.08 inch diameter phone tip plug.
H	ACTIVE/PICKUP LED	Red LED indicates sensed current has exceeded the TIME PICKUP setting. LED turns from red to green when sensed current falls below 95% of pickup setting. When the LED is green, the relay is active but has not picked up.
I	Target RESET Button	Linkage extends through back of front cover to reset both gravity latched target indicators.
J	SW3-1	SW3-1 selects the system operating frequency. Opening SW3-1 (OFF) selects 60 hertz operation. Closing SW3-1 (ON) selects 50 hertz operation.
	SW3-2	SW3-2 selects additional delay for the instantaneous element. Closing SW3-2 (ON) provides an additional instantaneous delay of 0.1 seconds.
	SW3-3	<u>100 Series Relays</u> Closing SW3-3 (ON) provides an additional instantaneous delay of 0.2 seconds. Closing both SW3-2 (ON) and SW3-3 (ON) provides an additional instantaneous delay of 0.3 seconds. <u>200 Series Relays</u> Opening SW3-3 (OFF) selects ABB type curves (refer to Table 1-3.) Closing SW3-3 (ON) selects GE IAC type curves (refer to Table 1-4).
	SW3-4	SW3-4 provides selection of either instantaneous or integrating reset characteristics. Closing SW3-4 (ON) selects integrating reset characteristics. Opening SW3-4 (OFF) selects instantaneous reset characteristics. See Section 1, <i>General Information, Specifications</i> , for details on time reset.

Locator	Control or Indicator	Function
K	Auxiliary Output Jumper Terminations	<p>Configures the auxiliary output contacts to close with either the instantaneous (50) trip and/or the timed (51) trip.</p> <p>Jumper E2 to E1A to close the auxiliary contact with the timed (51) trip. This jumper is yellow and factory installed to close the auxiliary output contacts with the timed trip.</p> <p>Jumper E3 to E1B to close the auxiliary contact with the instantaneous (50) trip. This jumper is blue and factory installed to close the auxiliary output contacts with the instantaneous trip.</p> <p>Users with unit revision R and previous in units 9252000100 through 109, refer to Section 6 for the location of the auxiliary output jumper terminations.</p> <p>Users with BE1-50/51B unit revisions Q, R, and S in 100 series relays and unit revisions H and previous in 200 series relays, refer to Section 6 for the location of the auxiliary output jumper terminations and the location of SW3. (Note: In all previous revisions, the reference designator for SW3 was SW8.)</p>

SECTION 3 • FUNCTIONAL DESCRIPTION

TABLE OF CONTENTS

SECTION 3 • FUNCTIONAL DESCRIPTION	3-1
GENERAL	3-1
FUNCTIONAL DESCRIPTION	3-1
Sensing Input.....	3-1
Power Supply	3-1
Instantaneous Signal.....	3-1
Time Signal.....	3-1
Microprocessor	3-1
Power-Off Sensing	3-1
Outputs	3-2

Figures

Figure 3-1. Functional Block Diagram	3-2
--	-----

This page intentionally left blank.

SECTION 3 • FUNCTIONAL DESCRIPTION

GENERAL

BE1-50/51B Overcurrent Relays are microprocessor based non-directional relays that measure ac current to provide secure and reliable instantaneous and time overcurrent protection for power systems.

FUNCTIONAL DESCRIPTION

Sensing Input

Single phase ac current from system current transformers (CT) is brought into the overcurrent relay at terminals 5 and 6. Refer to Figure 3-1 to follow the functional description. The input current is applied to internal power and signal CTs.

Power Supply

Current from the power CT is rectified, filtered, and supplied to all relay internal circuitry for operating power. A precision +5 Vdc supply also serves as a reference for automatic calibration.

Instantaneous Signal

Current from the signal CT is rectified and applied to the instantaneous scaling resistors controlled by the INST PICKUP selector switches. The analog voltage of the instantaneous input signal developed across the scaling resistors is filtered and applied to the multiplexor (MUX).

Time Signal

Current from the signal CT is also rectified and applied to the time scaling resistors controlled by the TIME PICKUP selector switches. The analog voltage of the time input signal is also filtered and applied to the multiplexor.

Microprocessor

Operating power from the power supply is applied to the microprocessor supervisor circuit. When the microprocessor is active and executing code, the ACTIVE/PICKUP LED is green. When the input current falls below an acceptable level, the supervisor circuit interrupts the microprocessor, halts further operation, and turns OFF the ACTIVE/PICKUP LED. A microprocessor watchdog feature resets the microprocessor program when the program flow is interrupted.

Information from the TIME DIAL selector switches, the TIME CURVE selector switch, INST DELAY switches, and RESET CHAR switch is also applied to the microprocessor. The microprocessor uses these inputs to set the operating parameters.

When the microprocessor is ready for analog information from the multiplexor, microprocessor control signals cause the multiplexor to route the desired input through to the output. The output is converted from an analog value to a digital value and applied to the microprocessor.

The microprocessor performs the program operations based on the inputs and the internal software program. When the sensed current exceeds the TIME PICKUP setting, the ACTIVE/PICKUP LED turns from green to red. TIME contacts (51 and 51 AUX) are closed in accordance with the TIME characteristic equation. If the sensed current exceeds the INST PICKUP setting, the INST contact (50) is closed.

Power-Off Sensing

In 200 series relays, power-off sensing circuits measure the decaying voltage to determine the length of time that power is removed (zero current). This provides information for the integrating reset function even when power has been entirely removed.

Instantaneous and Timed

System circuit breakers controlled by the output contacts can be manually tripped by applying a short across the TIME or INST MANUAL TRIP front panel test points. Current flow in the trip circuit is indicated by the operation of the target. The targets will not operate without adequate operating power for the relay.

CAUTION

Trip circuit voltage is present at the front panel test points. When shorting the test points, use insulated jumpers to avoid contact with these voltages.

Auxiliary

The auxiliary output contacts can be configured by the user to close when the timed and/or instantaneous trip occurs. With both jumpers installed (this is the factory setting) either the timed or instantaneous trip closes the auxiliary contacts. Effective with unit revision S, in units 9252000100 through 9252000109, the printed circuit board was changed. Now, the PCB for 100 and 200 series relays are similar. User's with units previous to revision R may see Section 6, Relay Differences, for installing auxiliary output contact jumpers.




Figure 3-1. Functional Block Diagram

SECTION 4 • INSTALLATION

TABLE OF CONTENTS

SECTION 4 • INSTALLATION	4-1
GENERAL	4-1
MOUNTING	4-1
CONNECTIONS	4-4
MAINTENANCE	4-7
STORAGE	4-7

Figures

Figure 4-1. Panel Drilling Diagram, A1 Case (Semi-Flush Mount).....	4-1
Figure 4-2. Outline Dimensions, A1 Case (Semi-Flush Mount)	4-2
Figure 4-3. Panel Drilling Diagram, S1 Case (Semi-Flush Mount).....	4-2
Figure 4-4. Outline Dimensions, S1 Case (Semi-Flush Mount)	4-3
Figure 4-5. Panel Drilling Diagram, S1 Case (Projection Mount).....	4-3
Figure 4-6. Outline Dimensions, S1 Case (Projection Mount)	4-4
Figure 4-7. AC Input Connections	4-5
Figure 4-8. DC Control Connections	4-6
Figure 4-9. BE1-50/51B Terminal Connections, Rear View	4-7

This page intentionally left blank.

SECTION 4 • INSTALLATION

GENERAL

When not shipped as part of a control or switchgear panel, the relays are shipped in sturdy cartons to prevent damage during transit. Immediately upon receipt of a relay, check the model and part number against the requisition and packing list to see that they agree. Visually inspect the relay for damage that may have occurred during shipment. If there is evidence of damage, immediately file a claim with the carrier and notify the Regional Sales Office, or contact the Sales Representative at Basler Electric, Highland, Illinois.

Proper operation of the relay may be confirmed by performing the operational test procedure of Section 5. If the relay won't be installed immediately, store the relay in its original shipping carton in a moisture and dust-free environment.

MOUNTING

Relay outline dimensions and panel drilling diagrams are shown in Figures 4-1 through 4-6.




Figure 4-1. Panel Drilling Diagram, A1 Case (Semi-Flush Mount)




Figure 4-2. Outline Dimensions, A1 Case (Semi-Flush Mount)







Figure 4-3. Panel Drilling Diagram, S1 Case (Semi-Flush Mount)





Note: Projection mount uses washers over the bosses as shown in this illustration.

Figure 4-6. Outline Dimensions, S1 Case (Projection Mount)


CONNECTIONS

Incorrect wiring may result in damage to the relay. Be sure to check model and part number before connecting and energizing a particular relay.

NOTE

Be sure that the relay is hard-wired to earth ground with no smaller than 12 AWG copper wire attached to the ground terminal on the rear of the unit case. When the relay is configured in a system with other devices, it is recommended to use a separate lead to the ground bus from each unit.

Connections should be made with minimum wire size of 14 AWG except as noted for the ground wire. Typical ac input and dc control connections are shown in Figures 4-7 and 4-8. The auxiliary output jumper configuration schematic diagram is also shown in Figure 4-8. Relay internal connections are shown on the back of the relay. Figure 4-9 shows a rear view of the relay and the connections.



D1147-17

LEGEND:

- 50/51B OVERCURRENT RELAY
- 52 POWER CIRCUIT BREAKER
- 51-N GROUND OVERCURRENT RELAY

Figure 4-7. AC Input Connections





Figure 4-8. DC Control Connections



Figure 4-9. BE1-50/51B Terminal Connections, Rear View

MAINTENANCE

BE1-50/51B overcurrent relays require no preventive maintenance. However, periodic checks should be performed according to scheduled practices. A recommended periodic test is provided in Section 5. If the relay fails to function properly, contact the Technical Sales Support Department of Basler Electric.

STORAGE

This protective relay contains long-life, aluminum, electrolytic capacitors. Life in excess of 20 years may be expected if the storage temperature does not exceed 40°C (104°F).

This page intentionally left blank.

SECTION 5 • TESTING

TABLE OF CONTENTS

SECTION 5 • TESTING	5-1
GENERAL	5-1
DIELECTRIC TEST	5-1
OPERATIONAL TEST PROCEDURE	5-1
Test Equipment Required.....	5-1
Test Procedure for Five Ampere Units.....	5-3
Test Procedure for One Ampere Units.....	5-5
SETTING THE RELAY	5-7
PERIODIC TESTS	5-7
General.....	5-7
Periodic Test.....	5-7
Figures	
Figure 5-1. Pickup and Timing Test Setup	5-2
Figure 5-2. Target Operational Test Setup.....	5-2

This page intentionally left blank.

SECTION 5 • TESTING

GENERAL

Dielectric testing, operational testing, and periodic testing are described in the following paragraphs.

DIELECTRIC TEST

In accordance with IEC 255-5 and IEEE C37.90-1989, one-minute dielectric (high potential) tests may be performed as follows:

- | | |
|---------------------------|-------------------------|
| All circuits to ground: | 2,828 Vdc. |
| Input to output circuits: | 2,000 Vac or 2,828 Vdc. |

Output contacts are surge protected.

OPERATIONAL TEST PROCEDURE

The following procedures verify operation of BE1-50/51B relays. The test setups of Figures 5-1 and 5-2 are intended primarily as an illustration of the principles involved. Other test setups known to be capable of testing with the stated and implied tolerances (including equipment specifically designed for testing relays) may be used.

Test Equipment Required

- Current source with a range from 0 to 20 Aac (sensing input current)
- Current source 0.2 to 3 Aac (target operation)
- Timer or counter

CAUTION

When testing units with integrating reset characteristics selected, timing may be affected by the integrating reset.




Figure 5-1. Pickup and Timing Test Setup




Figure 5-2. Target Operational Test Setup

NOTE

When testing TIME overcurrent functions, INST PICKUP settings of 00 will affect the calibration of the TIME functions. TIME PICKUP settings of 00 also affect INST functions.

Test Procedure for Five Ampere Units

TIME Pickup Test

Perform preliminary setup:

- Connect test setup as shown in Figure 5-1.
- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to OFF (selects instantaneous reset).
- Set TIME DIAL to 0.0.
- Set CURVE to S
- Set TIME PICKUP to 0.5.
- Set INST PICKUP to 90.

Step 1. Slowly increase current to terminals 8 and 9. ACTIVE/PICKUP LED should turn RED at a maximum input current of 0.550 ampere.

Step 2. Decrease input current until ACTIVE/PICKUP LED turns GREEN then OFF.

Step 3. Set TIME PICKUP to 2.2.

Step 4. Slowly increase current to terminals 8 and 9. ACTIVE/PICKUP LED should change from GREEN to RED at an input current of 2.131 to 2.269 amperes.

Step 5. Decrease input current until ACTIVE/PICKUP LED turns GREEN then OFF.

INST Pickup Test

Perform preliminary setup:

- Connect test setup as shown in Figure 5-1.
- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to OFF (selects instantaneous reset).
- Set TIME DIAL to 0.0.
- Set CURVE to S
- Set TIME PICKUP to 15.1.
- Set INST PICKUP to 01.

Step 1. Slowly increase current to terminals 8 and 9. INST contacts should close at an input current of 0.955 to 1.045 amperes.

Step 2. Decrease input current until INST output contacts open.

Step 3. Set INST PICKUP to 08.

Step 4. Slowly increase current to terminals 8 and 9. INST contacts should close at an input current of 7.815 to 8.185 amperes.

Step 5. Decrease input current until INST output contacts open.

Time Dial Test

Perform preliminary setup:

- Connect test setup as shown in Figure 5-1.
- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to OFF (selects instantaneous reset).
- Set TIME DIAL to 4.5.
- Set CURVE to S
- Set TIME PICKUP to 1.0.

- Set INST PICKUP to 90.

Step 1. Prepare to apply 1.5 amperes input current to terminals 8 and 9 and record the elapsed time from when current is applied until TIME output contacts close.

Step 2. Apply the current (step from 0 to 1.5 amperes) and record the elapsed time. Elapsed time should be 1.754 to 2.084 seconds. (This tolerance is greater than $\pm 2\%$ because it is the accumulation of both pickup and timing tolerances.)

Step 3. Remove input current.

Target Test

Perform preliminary setup:

- Connect test setup as shown in Figure 5-2.
- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to OFF (selects instantaneous reset).
- Set TIME DIAL to 4.5.
- Set CURVE to S
- Set TIME PICKUP to 1.0.
- Set INST PICKUP to 01.

Step 1. Set target current source to 1.0 ampere, ac.

Step 2. Apply 5 amperes input current to terminals 8 and 9. Check that both TIME and INST targets operate.

Step 3. Remove input current and reset targets.

Manual Trip Test

Perform preliminary setup:

- Connect test setup as shown in Figure 5-2.
- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to OFF (selects instantaneous reset).
- Set TIME DIAL to 4.5.
- Set CURVE to S
- Set TIME PICKUP to 1.0.
- Set INST PICKUP to 01.

CAUTION

Trip circuit voltage is present at the front panel test points. When shorting the test points, use insulated jumpers to avoid contact with these voltages.

Step 1. Set target current source to 1.0 ampere, ac.

Step 2. Apply 0.9 ampere input current to terminals 8 and 9.

Step 3. Connect a jumper between TIME MANUAL TRIP test points. Check that TIME target operates.

Step 4. Connect a jumper between INST MANUAL TRIP test points. Check that INST target operates.

Step 5. Reset targets.

Integrating Reset Test (Applicable Only to 200 Series Relays)

Perform preliminary setup:

- Connect test setup as shown in Figure 5-1.
- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to ON (selects integrating reset).
- Set TIME DIAL to 4.5.

- Set CURVE to I.
- Set TIME PICKUP to 1.0.
- Set INST PICKUP to 90.

Step 1. Set target current source to 1.0 ampere, ac.

Step 2. Read all of Step 3 before beginning Step 3.

Step 3. Apply 4.0 amperes input current to terminals 8 and 9. After the unit trips, remove the input current for 20 ± 0.25 seconds, then reapply the 4.0 amperes input current. Record the elapsed time from the re-application of input current to the output retrip.

Result: Elapsed time should be 1.55 ± 0.3 seconds.

Test Procedure for One Ampere Units

TIME Pickup Test

Perform preliminary setup:

- Connect test setup as shown in Figure 5-1.
- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to OFF (selects instantaneous reset).
- Set TIME DIAL to 0.0.
- Set CURVE to S
- Set TIME PICKUP to 0.1.
- Set INST PICKUP to 18.0.

Step 1. Slowly increase current to terminals 8 and 9. ACTIVE/PICKUP LED should turn RED at a maximum input current of 0.11 ampere.

Step 2. Decrease input current until ACTIVE/PICKUP LED turns GREEN then OFF.

Step 3. Set TIME PICKUP to 0.44.

Step 4. Slowly increase current to terminals 8 and 9. ACTIVE/PICKUP LED should change from GREEN to RED at an input current of 0.426 to 0.454 amperes.

Step 5. Decrease input current until ACTIVE/PICKUP LED turns GREEN then OFF.

INST Pickup Test

Perform preliminary setup:

- Connect test setup as shown in Figure 5-1.
- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to OFF (selects instantaneous reset).
- Set TIME DIAL to 0.0.
- Set CURVE to S
- Set TIME PICKUP to 3.02.
- Set INST PICKUP to 0.2.

Step 1. Slowly increase current to terminals 8 and 9. INST contacts should close at an input current of 0.191 to 0.209 amperes.

Step 2. Decrease input current until INST output contacts open.

Step 3. Set INST PICKUP to 1.6.

Step 4. Slowly increase current to terminals 8 and 9. INST contacts should close at an input current of 1.563 to 1.637 amperes.

Step 5. Decrease input current until INST output contacts open.

Time Dial Test

Perform preliminary setup:

- Connect test setup as shown in Figure 5-1.

- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to OFF (selects instantaneous reset).
- Set TIME DIAL to 4.5.
- Set CURVE to S
- Set TIME PICKUP to 0.2.
- Set INST PICKUP to 18.0.

Step 1. Prepare to apply 0.3 amperes input current to terminals 8 and 9 and record the elapsed time from when current is applied until TIME output contacts close.

Step 2. Apply the current (step from 0 to 0.3 amperes) and record the elapsed time. Elapsed time should be 1.754 to 2.084 seconds. (This tolerance is greater than $\pm 2\%$ because it is the accumulation of both pickup and timing tolerances.)

Step 3. Remove input current.

Target Test

Perform preliminary setup:

- Connect test setup as shown in Figure 5-2.
- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to OFF (selects instantaneous reset).
- Set TIME DIAL to 4.5.
- Set CURVE to S
- Set TIME PICKUP to 0.2.
- Set INST PICKUP to 0.2.

Step 1. Set target current source to 1.0 ampere, ac.

Step 2. Apply 1 ampere input current to terminals 8 and 9. Check that both TIME and INST targets operate.

Step 3. Remove input current and reset targets.

Manual Trip Test

Perform preliminary setup:

- Connect test setup as shown in Figure 5-2.
- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to OFF (selects instantaneous reset).
- Set TIME DIAL to 4.5.
- Set CURVE to S
- Set TIME PICKUP to 0.2.
- Set INST PICKUP to 0.2.

CAUTION

Trip circuit voltage is present at the front panel test points. When shorting the test points, use insulated jumpers to avoid contact with these voltages.

Step 1. Set target current source to 1.0 ampere, ac.

Step 2. Apply 0.15 ampere input current to terminals 8 and 9.

Step 3. Connect a jumper between TIME MANUAL TRIP test points. Check that TIME target operates.

Step 4. Connect a jumper between INST MANUAL TRIP test points. Check that INST target operates.

Step 5. Reset targets.

Integrating Reset Test (Applicable Only to 200 Series Relays)

Perform preliminary setup:

- Connect test setup as shown in Figure 5-1.
- Ensure that SW3 switches are set correctly: SW3-1 for operating frequency, SW3-2 to OFF (no instantaneous delay), SW3-3 to OFF (no instantaneous delay (100 series relays) or ABB type curves selected (200 series relays)), and SW3-4 to ON (selects integrating reset).
- Set TIME DIAL to 4.5.
- Set CURVE to I.
- Set TIME PICKUP to 0.2.
- Set INST PICKUP to 18.0.

Step 1. Set target current source to 1.0 ampere, ac.

Step 2. Read all of Step 3 before beginning Step 3.

Step 3. Apply 0.8 ampere input current to terminals 8 and 9. After the unit trips, remove the input current for 20 ± 0.25 seconds, then reapply the 0.8 ampere input current. Record the elapsed time from the re-application of input current to the output retrip.

Result: Elapsed time should be 1.55 ± 0.3 seconds.

SETTING THE RELAY

Select the desired relay settings before putting the relay into service. Changing pickup current settings while the relay is in service may cause tripping.

PERIODIC TESTS

General

All relays should be tested periodically to identify and correct any problems that are found.

Single phase relays such as the BE1-50/51B are normally used in groups of four (three phase and ground) on the protected circuit. This relay scheme allows each unit to be withdrawn one at a time for testing purposes without losing protection. Only three are required at any one time to sense all types of faults on a grounded wye system. Refer to Figures 5-1 and 5-2 for recommended test setups.

Periodic Test

Periodic testing should consist of the following procedures.

- Step 1. Verify that the instantaneous pickup is within $\pm 2\%$ of the value set on the dials. Pickup occurs when the INST output contacts close.
- Step 2. Verify that the time pickup is within $\pm 2\%$ of the value set on the dials. Pickup occurs when the LED turns GREEN then RED.
- Step 3. Verify that the time to trip for the curve and time dial settings at a multiple of six is the same as the time given on the characteristic curve. Refer to Appendix A for the characteristics curves.
- Step 4. Verify that the time to trip for the instantaneous element at a pickup multiple of 2 is not greater than the time given on the instantaneous characteristic curve. Refer to Section 1 for the instantaneous characteristic curve.
- Step 5. Verify that the 51 AUX contacts close when the time overcurrent element trips.
- Step 6. Verify that the targets operate with one ac ampere of trip current in the trip circuits and that they can be reset using the RESET BUTTON.

This page intentionally left blank.

SECTION 6 • RELAY DIFFERENCES

TABLE OF CONTENTS

SECTION 6 • RELAY DIFFERENCES.....	6-1
GENERAL.....	6-1
DIFFERENCES.....	6-1

Figures

Figure 6-1. Location of Controls and Indicators for unit revision Q and Previous, 100 Series Relays	6-2
Figure 6-2. Location of Controls and Indicators for Unit Revisions R, 100 Series Relays and Unit Revisions H and Previous, 200 Series Relays.....	6-3

This page intentionally left blank.

SECTION 6 • RELAY DIFFERENCES

GENERAL

This section provides the information necessary to support BE1-50/51B 100 series relays, revision S and previous. In all unit revisions R and previous SW3 is the same as SW8.

DIFFERENCES

BE1-50/51B 100 series relay boards revision Q and previous have the locations for controls and indicators shown in Figure 6-1. BE1-50/51B 100 series relays, unit revisions R and 200 series relays, unit revisions H and previous have the locations for controls and indicators shown in Figure 6-2. Table 6-1 lists and briefly describes the operator controls of these relays. Reference the callout letters to Figures 6-1 and 6-2.

Table 6-1. BE1-50/51B Controls and Indicators for 100 Series Relays Revision Q and Previous

Locator	Control or Indicator	Function
J	SW8-1	SW8-1 selects the system operating frequency. SW8-1 open (OFF) selects 60 hertz operation. SW8-1 closed (ON) selects 50 hertz operation.
	SW8-2	In 100 and 200 series relays, SW8-2 selects additional delay for the instantaneous element. Switch SW8-2 closed (ON) provides an additional instantaneous delay of 0.1 seconds.
	SW8-3	<p>In 100 series relays, switch SW8-3 closed (ON) provides an additional instantaneous delay of 0.2 seconds. Closing both switches SW8-2 and SW8-3 provides an additional instantaneous delay of 0.3 seconds.</p> <p>In 200 series relays, SW8-3 open (OFF) selects ABB type curves (refer to Table 1-3). SW8-3 closed (ON) selects GE IAC type curves (refer to Table 1-4).</p>
	SW8-4	Provides selection of either instantaneous or integrating reset characteristic. SW8-4 closed (ON) provides integrating reset. SW8-4 open (OFF) provides instantaneous reset.
K	Auxiliary Output Jumper Terminations	<p>Configures the auxiliary output contacts to close with either the instantaneous (50) trip and/or the timed (51) trip.</p> <p>Jumper E2 to E1A to close the auxiliary contact with the timed (51) trip. This jumper is yellow and factory installed to close the auxiliary output contacts with the timed trip.</p> <p>Jumper E3 to E1B to close the auxiliary contact with the instantaneous (50) trip. This jumper is blue and factory installed to close the auxiliary output contacts with the instantaneous trip.</p>





Figure 6-1. Location of Controls and Indicators for unit revision Q and Previous, 100 Series Relays



D1181-08

Figure 6-2. Location of Controls and Indicators for Unit Revisions R, 100 Series Relays and Unit Revisions H and Previous, 200 Series Relays

This page intentionally left blank.

APPENDIX A • TIME CHARACTERISTIC CURVES

TABLE OF CONTENTS

APPENDIX A • TIME CHARACTERISTIC CURVES	A-1
TIME CHARACTERISTIC CURVES	A-1

Figures

Figure A-1. Time Characteristic Curve, S-Short Inverse (SW3-3 OFF, Similar to ABB CO-2)	A-1
Figure A-2. Time Characteristic Curve, L-Long Inverse (SW3-3 OFF, Similar to ABB CO-5)	A-2
Figure A-3. Time Characteristic Curve, D-Definite Time (Similar to ABB CO-6)	A-3
Figure A-4. Time Characteristic Curve, M-Moderately Inverse (Similar to ABB CO-7)	A-4
Figure A-5. Time Characteristic Curve, I-Inverse (SW3-3 OFF, Similar to ABB CO-8)	A-5
Figure A-6. Time Characteristic Curve, V-Very Inverse (SW3-3 OFF, Similar to ABB CO-9)	A-6
Figure A-7. Time Characteristic Curve, E-Extremely Inverse (SW3-3 OFF, Similar to ABB CO-11)	A-7
Figure A-8. Time Characteristic Curve, BS142-B (BS142 Very Inverse)	A-8
Figure A-9. Time Characteristic Curve, BS142-C (BS142 Extremely Inverse)	A-9
Figure A-10. Time Characteristic Curve, S2-Short Inverse (SW3-3 ON, Similar to GE IAC 55)	A-10
Figure A-11. Time Characteristic Curve, L2-Long Inverse (SW3-3 ON, Similar to GE IAC 66)	A-11
Figure A-12. Time Characteristic Curve, I2-Inverse (SW3-3 ON, Similar to GE IAC 51)	A-12
Figure A-13. Time Characteristic Curve, V2-Very Inverse (SW3-3 ON, Similar to GE IAC 53)	A-13
Figure A-14. Time Characteristic Curve, E2-Extremely Inverse (SW3-3 ON, Similar to GE IAC 77)	A-14

This page intentionally left blank.

APPENDIX A • TIME CHARACTERISTIC CURVES

TIME CHARACTERISTIC CURVES

Figures A-1 through A-9 illustrate the time characteristic curves that are programmed into the nonvolatile memory of series 100 relays. Figures A-1 through A-14 illustrate the characteristic curves that are programmed into the nonvolatile memory of series 200 relays.




Figure A-1. Time Characteristic Curve, S-Short Inverse
(SW3-3 OFF, Similar to ABB CO-2)




Figure A-2. Time Characteristic Curve, L-Long Inverse
(SW3-3 OFF, Similar to ABB CO-5)




Figure A-3. Time Characteristic Curve, D-Definite Time
(Similar to ABB CO-6)




Figure A-4. Time Characteristic Curve, M-Moderately Inverse
(Similar to ABB CO-7)




Figure A-5. Time Characteristic Curve, I-Inverse
(SW3-3 OFF, Similar to ABB CO-8)




Figure A-6. Time Characteristic Curve, V-Very Inverse
(SW3-3 OFF, Similar to ABB CO-9)




Figure A-7. Time Characteristic Curve, E-Extremely Inverse
(SW3-3 OFF, Similar to ABB CO-11)




Figure A-8. Time Characteristic Curve, BS142-B
(BS142 Very Inverse)




Figure A-9. Time Characteristic Curve, BS142-C
(BS142 Extremely Inverse)




Figure A-10. Time Characteristic Curve, S2-Short Inverse
(SW3-3 ON, Similar to GE IAC 55)




Figure A-11. Time Characteristic Curve, L2-Long Inverse
(SW3-3 ON, Similar to GE IAC 66)




Figure A-12. Time Characteristic Curve, I₂-Inverse
(SW3-3 ON, Similar to GE IAC 51)




Figure A-13. Time Characteristic Curve, V2-Very Inverse
(SW3-3 ON, Similar to GE IAC 53)




Figure A-14. Time Characteristic Curve, E2-Extremely Inverse
(SW3-3 ON, Similar to GE IAC 77)

www.ElectricalPartManuals.com



ROUTE 143, BOX 269

HIGHLAND, IL 62249 USA

<http://www.basler.com>, info@basler.com

PHONE +1 618-654-2341

FAX +1 618-654-2351