



INSTALLATION • OPERATION • MAINTENANCE INSTRUCTIONS

TYPE COV VOLTAGE CONTROLLED OVERCURRENT RELAY

CAUTION Before putting relays into service, remove all blocking which may have been inserted for the purpose of securing the parts during shipment, make sure that all moving parts operate freely, inspect the contacts to see that they are clean and close properly, and operate the relay to check the settings and electrical connections.

APPLICATION

The type COV relay is applicable where it is desired that an overcurrent unit be set to operate on less than full load current when the voltage falls below a predetermined value, and it is desired not to operate for any magnitude of current when the voltage is above the predetermined value. A typical application is overcurrent back-up protection on generators.

CONTENTS

This instruction leaflet applies to the following types of relays:

Type COV-6 Definite Minimum Time Relay		
Type COV-7 Moderately Inverse	"	"
Type COV-8 Inverse	"	"
Type COV-9 Very Inverse	"	"

CONSTRUCTION AND OPERATION

The relay consists of an overcurrent unit, a voltage unit with adjustable resistor, an indicating contactor switch unit and an indicating instantaneous trip unit when required.

A. OVERCURRENT UNIT (CO)

The overcurrent unit operates on the induction principle. A main tapped coil located on the center leg of an "E" type laminated structure produces a flux which divides and returns through the outer legs. A shading coil causes the flux through the left leg to lag the main pole flux. The out-of-phase fluxes thus produced in the air gap cause a contact closing torque.

B. INDICATING CONTACTOR SWITCH UNIT (ICS)

The indicating contactor switch is a small d-c operated clapper type device. A magnetic armature, to which leaf-spring mounted contacts are attached, is attracted to the magnetic core upon energization of the switch. When the switch closes, the moving contacts bridge two stationary contacts, completing the trip circuit. Also during this operation two fingers on the armature deflect a spring located on the front of the switch, which allows the operation in-

dicator target to drop. The target is reset from the outside of the case by a push rod located at the bottom of the cover.

The front spring, in addition to holding the target, provides restraint for the armature and thus controls the pickup value of the switch.

C. INDICATING INSTANTANEOUS TRIP UNIT (IIT)

The instantaneous trip unit is a small a-c operated clapper type device. A magnetic armature, to which leaf-spring mounted contacts are attached, is attracted to the magnetic core upon energization of the switch. When the switch closes, the moving contacts bridge two stationary contacts completing the trip circuit. Also during the operation two fingers on the armature deflect a spring located on the front of the switch which allows the operation indicator target to drop. The target is reset from the outside of the case by a push rod located at the bottom of the cover.

A core screw accessible from the top of the switch provides the adjustable pickup range. The minimum and maximum pickup points are indicated on the scale which is located to the rear of the core screw.

D. VOLTAGE UNIT (V)

The voltage unit is an induction cylinder type unit.

Mechanically, the voltage unit is composed of four basic components: A die-cast aluminum frame, an electromagnet, a moving element assembly, and a molded bridge.

The frame serves as the mounting structure for the magnetic core. The magnetic core which houses the lower pin bearing is secured to the frame by a locking nut. The bearing can be replaced, if necessary, without having to remove the magnetic core from the frame.

The electromagnet has two pairs of voltage coils. Each pair of diametrically opposed coils is connected in series. In addition; one pair is in series with an adjustable resistor. These sets are paralleled as shown in Fig. 1. The adjustable resistor serves not only to shift the phase angle of the one flux with respect to the other to produce torque, but it also provides a pickup adjustment.

Locating pins in the electromagnet are used to accurately position the lower pin bearing, which is mounted on the frame, with respect to the upper pin bearing, which is threaded into the bridge. The electromagnet is secured to the frame by four mounting screws.





Fig. 1. Internal Schematic of the Type COV Relay in the Type FT21 Case.

Fig. 2. Internal Schematic of the Type COV Relay with Indicating Instantaneous Trip Unit in the Type FT21 Case.

The moving element assembly consists of a spiral spring, contact carrying member, and an aluminum cylinder assembled to a molded hub which holds the shaft. The shaft has removable top and bottom jewel bearings. The shaft rides between the bottom pin bearing and the upper pin bearing with the cylinder rotating in an air gap formed by the electromagnet and the magnetic core. The stops for the moving element contact arm are an integral part of the bridge.

The bridge is secured to the electromagnet and frame by two mounting screws. In addition to holding the upper pin bearing, the bridge is used for mounting the adjustable stationary contact housing. The stationary contact housing is held in position by a spring type clamp. The spring adjuster is located on the underside of the bridge and is attached to the moving contact arm by a spiral spring. The spring adjuster is also held in place by a spring type clamp.

With the contacts closed, the electrical connection is made through the stationary contact housing clamp, to the moving contact, through the spiral spring out to the spring adjuster clamp.

CHARACTERISTICS

To prevent the relay from operating for currents above the overcurrent unit pick-up, the voltage unit contact is connected in the shading coil circuit of the overcurrent unit. The voltage contact is held open at voltages above the set point, to prevent torque from being produced in the overcurrent unit. This arrangement yields a tripping characteristic as shown in Fig. 3.

OVERCURRENT UNIT

The relays are generally available in the following overcurrent unit current ranges:

<u>Range</u>	<u>Taps</u>						
0.5 — 2.5	0.5	0.6	0.8	1.0	1.5	2.0	2.5
2 — 6	2	2.5	3	3.5	4	5	6
4 — 12	4	5	6	7	8	10	12

The tap value is the minimum current required to just close the relay contacts.

These relays may have either single or double circuit closing contacts for tripping either one or two circuit breakers.

The time vs. current characteristics are shown in Figs. 4 to 7. These characteristics give the contact closing time for the various time dial settings when the indicated multiples of tap value current are applied to the relay.

VOLTAGE UNIT

The contact can be adjusted to close over a range of 80 to 100 volts. The contact opens if the voltage is higher than the set value. The drop-out ratio of the unit is 98% or higher.

TRIP CIRCUIT

The main contacts will safely close 30 amperes at 250 volts d-c and the seal-in contacts of the indicating contactor switch will safely carry this current long enough to trip a circuit breaker.

The indicating instantaneous trip contacts will safely close 30 amperes at 250 volts d-c, and will carry this current long enough to trip a breaker.

The indicating contactor switch has two taps that provide a pickup setting of 0.2 or 2 amperes. To change taps requires connecting the lead located in front of the tap block to the desired setting by means

of a screw connection.

TRIP CIRCUIT CONSTANTS

Indicating Contactor Switch —

0.2 amp tap 6.5 ohms d-c resistance

2.0 amp tap 0.15 ohms d-c resistance




Fig. 3. Typical Tripping Characteristics of Type COV Relay.

ENERGY REQUIREMENTS

COV-6 OVERCURRENT UNITS

		VOLT AMPERES**						
Ampere Range	Tap	Continuous Rating (Amperes)	One Second Rating * (Amperes)	Power Factor Angle ϕ	At Tap Value Current	At 3 Times Tap Value Current	At 10 Times Tap Value Current	At 20 Times Tap Value Current
0.5/2.5	(0.5	2	56	69	3.92	20.6	103	270
	(0.6	2.2	56	68	3.96	20.7	106	288
	(0.8	2.5	56	67	3.96	21	114	325
	(1.0	2.8	56	66	4.07	21.4	122	360
	(1.5	3.4	56	62	4.19	23.2	147	462
	(2.0	4.0	56	60	4.30	24.9	168	548
	(2.5	4.4	56	58	4.37	26.2	180	630
2/6	(2	8	230	67	3.88	21	110	308
	(2.5	8.8	230	66	3.87	21.6	118	342
	(3	9.7	230	64	3.93	22.1	126	381
	(3.5	10.4	230	63	4.09	23.1	136	417
	(4	11.2	230	62	4.08	23.5	144	448
	(5	12.5	230	59	4.20	24.8	162	540
	(6	13.7	230	57	4.38	26.5	183	624
4/12	(4	16	460	65	4.00	22.4	126	376
	(5	18.8	460	63	4.15	23.7	143	450
	(6	19.3	460	61	4.32	25.3	162	531
	(7	20.8	460	59	4.27	26.4	183	611
	(8	22.5	460	56	4.40	27.8	204	699
	(10	25	460	53	4.60	30.1	247	880
	(12	28	460	47	4.92	35.6	288	1056

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.

ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.

ENERGY REQUIREMENTS

COV-7 OVERCURRENT UNITS

		VOLT AMPERES**						
Ampere Range	Tap	Continuous Rating (Amperes)	One Second Rating* (Amperes)	Power Factor Angle ϕ	At Tap Value Current	At 3 Times Tap Value Current	At 10 Times Tap Value Current	At 20 Times Tap Value Current
0.5/2.5	(0.5	2	56	68	3.88	20.7	103	278
	(0.6	2.2	56	67	3.93	20.9	107	288
	(0.8	2.5	56	66	3.93	21.1	114	320
	(1.0	2.8	56	64	4.00	21.6	122	356
	(1.5	3.4	56	61	4.08	22.9	148	459
	(2.0	4.0	56	58	4.24	24.8	174	552
	(2.5	4.4	56	56	4.38	25.9	185	640
2/6	(2	8	230	66	4.06	21.3	111	306
	(2.5	8.8	230	63	4.07	21.8	120	342
	(3	9.7	230	63	4.14	22.5	129	366
	(3.5	10.4	230	62	4.34	23.4	141	413
	(4	11.2	230	61	4.34	23.8	149	448
	(5	12.5	230	59	4.40	25.2	163	530
	(6	13.7	230	58	4.62	27	183	624
4/12	(4	16	460	64	4.24	22.8	129	392
	(5	18.8	460	61	4.30	24.2	149	460
	(6	19.3	460	60	4.62	25.9	168	540
	(7	20.8	460	58	4.69	27.3	187	626
	(8	22.5	460	55	4.80	29.8	211	688
	(10	25	460	51	5.20	33	260	860
	(12	28	460	46	5.40	37.5	308	1032

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.

ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.

TYPE COV RELAY

COV-8, COV-9 OVERCURRENT UNITS

VOLT AMPERES**

Ampere Range	Tap	Continuous Rating (Amperes)	One Second Rating* (Amperes)	Power Factor Angle ϕ	At Tap Value Current	At 3 Times Tap Value Current	At 10 Times Tap Value Current	At 20 Times Tap Value Current
0.5/2.5	(0.5	2	56	72	2.38	21	132	350
	(0.6	2.2	56	71	2.38	21	134	365
	(0.8	2.5	56	69	2.40	21.1	142	400
	(1.0	2.8	56	67	2.42	21.2	150	440
	(1.5	3.4	56	62	2.51	22	170	530
	(2.0	4.0	56	57	2.65	23.5	200	675
	(2.5	4.4	56	53	2.74	24.8	228	800
2/6	(2	8	230	70	2.38	21	136	360
	(2.5	8.8	230	66	2.40	21.1	142	395
	(3	9.7	230	64	2.42	21.5	149	430
	(3.5	10.4	230	62	2.48	22	157	470
	(4	11.2	230	60	2.53	22.7	164	500
	(5	12.5	230	58	2.64	24	180	580
	(6	13.7	230	56	2.75	25.2	198	660
4/12	(4	16	460	68	2.38	21.3	146	420
	(5	18.8	460	63	2.46	21.8	158	480
	(6	19.3	460	60	2.54	22.6	172	550
	(7	20.8	460	57	2.62	23.6	190	620
	(8	22.5	460	54	2.73	24.8	207	700
	(10	25	460	48	3.00	27.8	248	850
	(12	28	460	45	3.46	31.4	292	1020

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.

ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.

VOLTAGE UNIT

Frequency	Drop-Out Adjustment Volts	Maximum Volts Continuous	Volt-Ampere + Burden at 120 volts	Drop-Out Ratio
60	80-100	132	8.0	98%

+ Volt-Ampere burden is average for the various settings.




Fig. 4. Typical 50 and 60 Cycle Time Curves of COV-6 Overcurrent Unit.




Fig. 7. Typical 50 and 60 Cycle Time Curves of COV-9 Overcurrent Unit.




Fig. 8. Diagram of Test Connections of the Overcurrent Unit.

SETTINGS

A. OVERCURRENT UNIT (CO)

The overcurrent unit settings can be defined either by tap settings and time dial position or by tap setting and a specific time of operation at some current multiple of the tap setting (e.g. 4 tap setting, 2 time dial position or 4 tap setting, 0.6 seconds at 5 times tap value current).

To provide selective circuit breaker operation, a minimum coordinating time of 0.3 seconds plus breaker time is recommended between the relay being set and the relays with which coordination is to be effected.

The connector screw on the terminal plate above the time dial makes connections to various turns on the operating coil. By placing this screw in the various terminal plate holes, the relay will just close its contacts at the corresponding current 4-5-6-7-8-10-12 amperes, or as marked on the terminal plate.

CAUTION

Since the tap block connector screw carries operating current, be sure that the screw is turned tight. In order to avoid opening the current transformer circuits when changing taps under load, connect the spare tap screw in the desired tap position by removing the other tap screw from the original tap position.

INSTANTANEOUS RECLOSING

The factory adjustment of the overcurrent unit contact provides a contact follow. Where instantaneous circuit breaker reclosing will be initiated upon the closure of the overcurrent contact, this contact




Fig. 9. External Schematic of the Type COV Relay on a Generator.

follow must be eliminated by loosening the stationary contact mounting screw, removing the contact plate then replacing the plate with the bent end resting against the contact spring. With this change and the contact mounting screw tightened, the stationary contact will rest solidly against its backstop.

B. INDICATING CONTACTOR SWITCH (ICS)

No setting is required on the ICS unit except the selection of the 0.2 to 2.0 ampere tap setting. This selection is made by connecting the lead located in front of the tap block to the desired setting by means of the connecting screw.

C. INDICATING INSTANTANEOUS TRIP (IIT)

Since the minimum and maximum markings on the scale only indicate the working range of the core screw, the core screw must be adjusted to the value of pick-up desired.

The nameplate data will furnish the actual current range that may be obtained from IIT unit.

D. VOLTAGE UNIT (V)

The voltage unit is calibrated to close its contact

when the applied voltage is reduced to 80 volts. The voltage unit can be set to close its contacts from 80 volts to 100 volts by adjusting the resistor located at the rear of the voltage unit. The spiral spring is not disturbed when making any setting other than the calibrated setting of 80 volts.

INSTALLATION

The relays should be mounted on switchboard panels or their equivalent in a location free from dirt, moisture, excessive vibration and heat. Mount the relay vertically by means of the two mounting studs for the type R^T projection case or by means of the four mounting holes on the flange for the semi-flush type R^T case. Either of the studs or the mounting screws may be utilized for grounding the relay. The electrical connections may be made directly to the terminals by means of screws for steel panel mounting or to terminal studs furnished with the relay for thick panel mounting. The terminal studs may be easily removed or inserted by locking two nuts on the studs and then turning the proper nut with a wrench.

The external a-c connections of the directional overcurrent relays are shown in Figs. 18 to 21.

ADJUSTMENTS AND MAINTENANCE

The proper adjustments to insure correct operation of this relay have been made at the factory. Upon receipt of the relay, no customer adjustments, other than those covered under "SETTINGS", should be required.

ACCEPTANCE CHECK

The following check is recommended to insure that the relay is in proper working order:

A. OVERCURRENT UNIT (CO)

The directional unit contacts must be in the closed position when checking the operation of the overcurrent unit.

1. Contacts — By turning the time dial, move the moving contacts until they deflect the stationary contact to a position where the stationary contact is just resting against its backstop. The index mark located on the movement frame should coincide with the "0" mark on the time dial.

2. Minimum Trip Current — Set the time dial to position 6. Alternately apply tap value current plus 3% and tap value current minus 3%. The moving contact should leave the backstop at tap value current plus 3% and should return to the backstop at tap value current minus 3%.

3. Time Curve — Table 1 shows the time curve calibration points for the various types of relays. With the time dial set to the indicated position, apply the currents specified by Table 1 (e.g. for the CR-8, 2 and 20 times tap value current) and measure the operating time of the relay. The operating times should equal those of Table 1 plus or minus 5 percent.

B. INDICATING CONTACTOR SWITCH (ICS) — Close the main relay contacts and pass sufficient d-c current through the trip circuit to close the contacts of the ICS. This value of current should not be greater than the particular ICS tap setting being used. The indicator target should drop freely.

C. INDICATING INSTANTANEOUS TRIP UNIT (IIT) — The core screw which is adjustable from the top of the trip unit determines the pickup value. The trip unit has a nominal ratio of adjustment of 1 to 4 and an accuracy within the limits of 10%.

Apply sufficient current to operate the IIT. The indicator target should drop freely.

D. VOLTAGE UNIT (V)

1. Contact Gap — The gap between the stationary contact and moving contact with the relay in a de-energized position should be approximately .020".

2. Sensitivity — The contacts should close when voltage is reduced to approximately 80 volts.

ROUTINE MAINTENANCE

All relays should be inspected periodically and the time of operation should be checked at least once every year or at such other time intervals as may be dictated by experience to be suitable to the particular application. Phantom loads should not be used in testing induction-type relays because of the resulting distorted current wave form which produces an error in timing.

All contacts should be periodically cleaned. A contact burnisher S#182A836H01 is recommended for this purpose. The use of abrasive material for cleaning contacts is not recommended, because of the danger of embedding small particles in the face of the soft silver and thus impairing the contact.

CALIBRATION

Use the following procedure for calibrating the relay if the relay has been taken apart for repairs or the adjustments have been disturbed. This procedure should not be used unless it is apparent that the relay is not in proper working order. (See "Acceptance Check").

A. OVERCURRENT UNIT (CO)

1. Contacts — By turning the time dial move the moving contacts until they deflect the stationary contact to a position where the stationary contact is just resting against its backstop. The index mark located on the movement frame should coincide with the "0" mark on the time dial.

2. Minimum Trip Current — The adjustment of the spring tension in setting the minimum trip current value of the relay is most conveniently made with the damping magnet removed.

With the time dial set on "0", wind up the spiral spring by means of the spring adjuster until approxi-

mately 6-3/4 convolutions show.

Set the relay on the minimum tap setting, the time dial to position 6.

Adjust the control spring tension so that the moving contact will leave the backstop at tap value current + 1.0% and will return to the backstop at tap value current - 1.0%.

3. Time Curve Calibration - Install the permanent magnet.

Apply the indicated current per Table 1 for the permanent magnet adjustment (e.g. CR-8, 2 times tap value) and measure the operating time. Adjust the permanent magnet keeper until the operating time corresponds to the value of Table 2.

Apply the indicated current per Table 1 for the electromagnet plug adjustment (e.g. CR-8, 20 times tap value) and measure the operating time. Adjust the proper plug until the operating time corresponds to the value in Table 2. (Withdrawing the left-hand plug, front view, increases the operating time and withdrawing the right-hand plug, front view, decreases the time.) In adjusting the plugs, one plug should be screwed in completely and the other plug run in or out until the proper operating time has been obtained.

Recheck the permanent magnet adjustment. If the operating time for this calibration point has changed, readjust the permanent magnet and then recheck the electromagnet plug adjustment.

B. INDICATING CONTACTOR SWITCH - UNIT (ICS)

Close the main relay contacts and pass sufficient d-c current through the trip circuit to close the contacts of the ICS. This value of current should be not greater than the particular ICS tap setting being used. The indicator target should drop freely.

C. INDICATING INSTANTANEOUS TRIP UNIT (IIT)

Since the minimum and maximum markings on the scale only indicate the working range of the core screw, the core screw must be adjusted to the value of pick-up current desired.

The nameplate data will furnish the actual current

range that may be obtained from IIT unit.

D. VOLTAGE UNIT (V)

1. The upper pin bearing should be screwed down until there is approximately 1/64" clearance between it and the top of shaft bearing. The upper pin bearing should then be securely locked in position with the lock nut. The lower bearing position is fixed and cannot be adjusted.

2. The contact gap adjustment for the directional unit is made as follows:

With the moving contact in the normally-closed position, i.e. against the left stop on bridge, screw in the stationary contact until both contacts just close as indicated by a neon lamp in the contact circuit. Then, screw the stationary contact in towards the moving contact an additional one-half turn. The clamp holding the stationary contact housing need not be loosened for the adjustment since the clamp utilizes a spring-type action in holding the stationary contact in position.

3. The sensitivity adjustment is made in two steps.

A. The adjustable resistor, located at the rear of the voltage unit, is adjusted such that the maximum resistance is in the circuit (Approximately 2500 ohms).

B. The tension of the spiral spring, attached to the moving element assembly, is then varied. The spring is adjusted by placing a screwdriver or similar tool into one of the notches located on the periphery of the spring adjuster and rotating it. The spring adjuster is located on the underside of the bridge and is held in place by a spring type clamp that does not have to be loosened prior to making the necessary adjustments.

The spring is to be adjusted such that the contacts will close as indicated by a neon lamp in the contact circuit when the applied voltage is reduced to 80 volts. The contacts should open with 80 plus volts applied.


Any setting other than the 80 volts then can be made by adjusting the resistor for the desired contact closing voltage.

TABLE 1
TIME CURVE CALIBRATION DATA - 50-60 CYCLES FOR
OVERCURRENT UNIT

		Permanent Magnet Adjustment		Electromagnet Plug Adjustment	
Relay Type	Time Dial Position	Current (Multiples of Tap Value)	Operating Time	Current (Multiples of Tap Value)	Operating Time
6	6	2	2.46	20	1.19
7	6	2	4.27	20	1.11
8	6	2	13.35	20	1.11
9	6	2	8.87	20	0.65

RENEWAL PARTS

Repair work can be done most satisfactorily at the factory. However, interchangeable parts can be furnished to the customers who are equipped for doing repair work. When ordering parts, always give the complete nameplate data.



57-D-7901

Fig. 10. Outline and Drilling Plan for the Type COV Relay in Type FT21 Case.



WESTINGHOUSE ELECTRIC CORPORATION

METER DIVISION



NEWARK, N.J.

Printed in U. S. A.



INSTALLATION • OPERATION • MAINTENANCE INSTRUCTIONS

TYPE COV VOLTAGE CONTROLLED OVERCURRENT RELAY

CAUTION Before putting relays into service, remove all blocking which may have been inserted for the purpose of securing the parts during shipment, make sure that all moving parts operate freely, inspect the contacts to see that they are clean and close properly, and operate the relay to check the settings and electrical connections.

APPLICATION

The type COV relay is applicable where it is desired that an overcurrent unit be set to operate on less than full load current when the voltage falls below a predetermined value, and it is desired not to operate for any magnitude of current when the voltage is above the predetermined value. A typical application is overcurrent back-up protection on generators.

CONTENTS

This instruction leaflet applies to the following types of relays:

Type COV-6 Definite Minimum Time Relay		
Type COV-7 Moderately Inverse	"	"
Type COV-8 Inverse	"	"
Type COV-9 Very Inverse	"	"

CONSTRUCTION AND OPERATION

The relay consists of an overcurrent unit, a voltage unit with adjustable resistor, an indicating contactor switch unit and an indicating instantaneous trip unit when required.

A. OVERCURRENT UNIT (CO)

The overcurrent unit operates on the induction principle. A main tapped coil located on the center leg of an "E" type laminated structure produces a flux which divides and returns through the outer legs. A shading coil causes the flux through the left leg to lag the main pole flux. The out-of-phase fluxes thus produced in the air gap cause a contact closing torque.

B. INDICATING CONTACTOR SWITCH UNIT (ICS)

The indicating contactor switch is a small d-c operated clapper type device. A magnetic armature, to which leaf-spring mounted contacts are attached, is attracted to the magnetic core upon energization of the switch. When the switch closes, the moving contacts bridge two stationary contacts, completing the trip circuit. Also during this operation two fingers on the armature deflect a spring located on the front of the switch, which allows the operation in-

dicator target to drop. The target is reset from the outside of the case by a push rod located at the bottom of the cover.

The front spring, in addition to holding the target, provides restraint for the armature and thus controls the pickup value of the switch.

C. INDICATING INSTANTANEOUS TRIP UNIT (IIT)

The instantaneous trip unit is a small a-c operated clapper type device. A magnetic armature, to which leaf-spring mounted contacts are attached, is attracted to the magnetic core upon energization of the switch. When the switch closes, the moving contacts bridge two stationary contacts completing the trip circuit. Also during the operation two fingers on the armature deflect a spring located on the front of the switch which allows the operation indicator target to drop. The target is reset from the outside of the case by a push rod located at the bottom of the cover.

A core screw accessible from the top of the switch provides the adjustable pickup range. The minimum and maximum pickup points are indicated on the scale which is located to the rear of the core screw.

D. VOLTAGE UNIT (V)

The voltage unit is an induction cylinder type unit.

Mechanically, the voltage unit is composed of four basic components: A die-cast aluminum frame, an electromagnet, a moving element assembly, and a molded bridge.

The frame serves as the mounting structure for the magnetic core. The magnetic core which houses the lower pin bearing is secured to the frame by a locking nut. The bearing can be replaced, if necessary, without having to remove the magnetic core from the frame.

The electromagnet has two pairs of voltage coils. Each pair of diametrically opposed coils is connected in series. In addition; one pair is in series with an adjustable resistor. These sets are paralleled as shown in Fig. 1. The adjustable resistor serves not only to shift the phase angle of the one flux with respect to the other to produce torque, but it also provides a pickup adjustment.

Locating pins in the electromagnet are used to accurately position the lower pin bearing, which is mounted on the frame, with respect to the upper pin bearing, which is threaded into the bridge. The electromagnet is secured to the frame by four mounting screws.

SUPERSEDES I.L. 41-116

EFFECTIVE MAY 1957

* Denotes change from superseded issue.




Fig. 1. Internal Schematic of the Type COV Relay in the Type FT21 Case.

The moving element assembly consists of a spiral spring, contact carrying member, and an aluminum cylinder assembled to a molded hub which holds the shaft. The shaft has removable top and bottom jewel bearings. The shaft rides between the bottom pin bearing and the upper pin bearing with the cylinder rotating in an air gap formed by the electromagnet and the magnetic core. The stops for the moving element contact arm are an integral part of the bridge.

The bridge is secured to the electromagnet and frame by two mounting screws. In addition to holding the upper pin bearing, the bridge is used for mounting the adjustable stationary contact housing. The stationary contact housing is held in position by a spring type clamp. The spring adjuster is located on the underside of the bridge and is attached to the moving contact arm by a spiral spring. The spring adjuster is also held in place by a spring type clamp.

With the contacts closed, the electrical connection is made through the stationary contact housing clamp, to the moving contact, through the spiral spring out to the spring adjuster clamp.

CHARACTERISTICS

To prevent the relay from operating for currents above the overcurrent unit pick-up, the voltage unit contact is connected in the shading coil circuit of the overcurrent unit. The voltage contact is held open at voltages above the set point, to prevent torque from being produced in the overcurrent unit. This arrangement yields a tripping characteristic as shown in Fig. 3.




Fig. 2. Internal Schematic of the Type COV Relay with Indicating Instantaneous Trip Unit in the Type FT21 Case.

OVERCURRENT UNIT

The relays are generally available in the following overcurrent unit current ranges:

Range	Taps						
0.5 — 2.5	0.5	0.6	0.8	1.0	1.5	2.0	2.5
2 — 6	2	2.5	3	3.5	4	5	6
4 — 12	4	5	6	7	8	10	12

The tap value is the minimum current required to just close the relay contacts.

These relays may have either single or double circuit closing contacts for tripping either one or two circuit breakers.

The time vs. current characteristics are shown in Figs. 4 to 7. These characteristics give the contact closing time for the various time dial settings when the indicated multiples of tap value current are applied to the relay.

VOLTAGE UNIT

The contact can be adjusted to close over a range of 80 to 100 volts. The contact opens if the voltage is higher than the set value. The drop-out ratio of the unit is 98% or higher.

TRIP CIRCUIT

The main contacts will safely close 30 amperes at 250 volts d-c and the seal-in contacts of the indicating contactor switch will safely carry this current long enough to trip a circuit breaker.

The indicating instantaneous trip contacts will safely close 30 amperes at 250 volts d-c, and will carry this current long enough to trip a breaker.

The indicating contactor switch has two taps that provide a pickup setting of 0.2 or 2 amperes. To change taps requires connecting the lead located in front of the tap block to the desired setting by means

of a screw connection.

TRIP CIRCUIT CONSTANTS

Indicating Contactor Switch —

0.2 amp tap 6.5 ohms d-c resistance

2.0 amp tap 0.15 ohms d-c resistance




Fig. 3. Typical Tripping Characteristics of Type COV Relay.

ENERGY REQUIREMENTS

COV-6 OVERCURRENT UNITS

Ampere Range	Tap	Continuous Rating (Amperes)	One Second Rating * (Amperes)	Power Factor Angle ϕ	VOLT AMPERES**			
					At Tap Value Current	At 3 Times Tap Value Current	At 10 Times Tap Value Current	At 20 Times Tap Value Current
0.5/2.5	(0.5	3.2	88	69	3.92	20.6	103	270
	(0.6	3.5	88	68	3.96	20.7	106	288
	(0.8	4.0	88	67	3.96	21	114	325
	(1.0	4.6	88	66	4.07	21.4	122	360
	(1.5	5.4	88	62	4.19	23.2	147	462
	(2.0	6.4	88	60	4.30	24.9	168	548
	(2.5	7.0	88	58	4.37	26.2	180	630
2/6	(2	8	230	67	3.88	21	110	308
	(2.5	8.8	230	66	3.87	21.6	118	342
	(3	9.7	230	64	3.93	22.1	126	381
	(3.5	10.4	230	63	4.09	23.1	136	417
	(4	11.2	230	62	4.08	23.5	144	448
	(5	12.5	230	59	4.20	24.8	162	540
	(6	13.7	230	57	4.38	26.5	183	624
4/12	(4	16	460	65	4.00	22.4	126	376
	(5	18.8	460	63	4.15	23.7	143	450
	(6	19.3	460	61	4.32	25.3	162	531
	(7	20.8	460	59	4.27	26.4	183	611
	(8	22.5	460	56	4.40	27.8	204	699
	(10	25	460	53	4.60	30.1	247	880
	(12	28	460	47	4.92	35.6	288	1056

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.

ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.

ENERGY REQUIREMENTS

COV-7 OVERCURRENT UNITS

					VOLT AMPERES**			
Ampere Range	Tap	Continuous Rating (Amperes)	One Second Rating* (Amperes)	Power Factor Angle ϕ	At Tap Value Current	At 3 Times Tap Value Current	At 10 Times Tap Value Current	At 20 Times Tap Value Current
0.5/2.5	(0.5	3.2	88	68	3.88	20.7	103	278
	(0.6	3.5	88	67	3.93	20.9	107	288
	(0.8	4.0	88	66	3.93	21.1	114	320
	(1.0	4.6	88	64	4.00	21.6	122	356
	(1.5	5.4	88	61	4.08	22.9	148	459
	(2.0	6.4	88	58	4.24	24.8	174	552
	(2.5	7.0	88	56	4.38	25.9	185	640
2/6	(2	8	230	66	4.06	21.3	111	306
	(2.5	8.8	230	63	4.07	21.8	120	342
	(3	9.7	230	63	4.14	22.5	129	366
	(3.5	10.4	230	62	4.34	23.4	141	413
	(4	11.2	230	61	4.34	23.8	149	448
	(5	12.5	230	59	4.40	25.2	163	530
	(6	13.7	230	58	4.62	27	183	624
4/12	(4	16	460	64	4.24	22.8	129	392
	(5	18.8	460	61	4.30	24.2	149	460
	(6	19.3	460	60	4.62	25.9	168	540
	(7	20.8	460	58	4.69	27.3	187	626
	(8	22.5	460	55	4.80	29.8	211	688
	(10	25	460	51	5.20	33	260	860
	(12	28	460	46	5.40	37.5	308	1032

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.

ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.

TYPE COV RELAY

COV-8, COV-9 OVERCURRENT UNITS

VOLT AMPERES**

Ampere Range	Tap	Continuous Rating (Amperes)	One Second Rating* (Amperes)	Power Factor Angle ϕ	At Tap Value Current	At 3 Times Tap Value Current	At 10 Times Tap Value Current	At 20 Times Tap Value Current
0.5/2.5	(0.5	3.2	88	72	2.38	21	132	350
	(0.6	3.5	88	71	2.38	21	134	365
	(0.8	4.0	88	69	2.40	21.1	142	400
	(1.0	4.6	88	67	2.42	21.2	150	440
	(1.5	5.4	88	62	2.51	22	170	530
	(2.0	6.4	88	57	2.65	23.5	200	675
	(2.5	7.0	88	53	2.74	24.8	228	800
2/6	(2	8	230	70	2.38	21	136	360
	(2.5	8.8	230	66	2.40	21.1	142	395
	(3	9.7	230	64	2.42	21.5	149	430
	(3.5	10.4	230	62	2.48	22	157	470
	(4	11.2	230	60	2.53	22.7	164	500
	(5	12.5	230	58	2.64	24	180	580
	(6	13.7	230	56	2.75	25.2	198	660
4/12	(4	16	460	68	2.38	21.3	146	420
	(5	18.8	460	63	2.46	21.8	158	480
	(6	19.3	460	60	2.54	22.6	172	550
	(7	20.8	460	57	2.62	23.6	190	620
	(8	22.5	460	54	2.73	24.8	207	700
	(10	25	460	48	3.00	27.8	248	850
	(12	28	460	45	3.46	31.4	292	1020

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.

ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.

VOLTAGE UNIT

Frequency	Drop-Out Adjustment Volts	Maximum Volts Continuous	Volt-Ampere + Burden at 120 volts	Drop-Out Ratio
60	80-100	132	8.0	98%

+ Volt-Ampere burden is average for the various settings.






Fig. 4. Typical 50 and 60 Cycle Time Curves of COV-6 Overcurrent Unit.




418247

Fig. 5. Typical 50 and 60 Cycle Time Curves of COV-7 Overcurrent Unit.



418248

Fig. 6. Typical 50 and 60 Cycle Time Curves of COV-8 Overcurrent Unit.



418249

Fig. 7. Typical 50 and 60 Cycle Time Curves of COV-9 Overcurrent Unit.




Fig. 8. Diagram of Test Connections of the Overcurrent Unit.

SETTINGS

A. OVERCURRENT UNIT (CO)

The overcurrent unit settings can be defined either by tap settings and time dial position or by tap setting and a specific time of operation at some current multiple of the tap setting (e.g. 4 tap setting, 2 time dial position or 4 tap setting, 0.6 seconds at 6 times tap value current).

To provide selective circuit breaker operation, a minimum coordinating time of 0.3 seconds plus breaker time is recommended between the relay being set and the relays with which coordination is to be effected.

The connector screw on the terminal plate above the time dial makes connections to various turns on the operating coil. By placing this screw in the various terminal plate holes, the relay will just close its contacts at the corresponding current 4-5-6-7-8-10-12 amperes, or as marked on the terminal plate.

CAUTION

Since the tap block connector screw carries operating current, be sure that the screw is turned tight. In order to avoid opening the current transformer circuits when changing taps under load, connect the spare tap screw in the desired tap position before removing the other tap screw from the original tap position.

INSTANTANEOUS RECLOSING

The factory adjustment of the overcurrent unit contact provides a contact follow. Where instantaneous circuit breaker reclosing will be initiated upon the closure of the overcurrent contact, this contact




Fig. 9. External Schematic of the Type COV Relay on a Generator.

follow must be eliminated by loosening the stationary contact mounting screw, removing the contact plate then replacing the plate with the bent end resting against the contact spring. With this change and the contact mounting screw tightened, the stationary contact will rest solidly against its backstop.

- * For double trip relays, the upper stationary contact is adjusted such that the contact rests solidly against the back stop. The lower stationary contact is then adjusted such that both stationary contacts make contact simultaneously with their respective moving contact.

B. INDICATING CONTACTOR SWITCH (ICS)

No setting is required on the ICS unit except the selection of the 0.2 to 2.0 ampere tap setting. This selection is made by connecting the lead located in front of the tap block to the desired setting by means of the connecting screw.

C. INDICATING INSTANTANEOUS TRIP (IIT)

Since the minimum and maximum markings on the scale only indicate the working range of the core

TYPE COV RELAY

screw, the core screw must be adjusted to the value of pick-up desired.

The nameplate data will furnish the actual current range that may be obtained from IIT unit.

D. VOLTAGE UNIT (V)

The voltage unit is calibrated to close its contact when the applied voltage is reduced to 80 volts. The voltage unit can be set to close its contacts from 80 volts to 100 volts by adjusting the resistor located at the rear of the voltage unit. The spiral spring is not disturbed when making any setting other than the calibrated setting of 80 volts.

INSTALLATION

The relays should be mounted on switchboard panels or their equivalent in a location free from dirt, moisture, excessive vibration and heat. Mount the relay vertically by means of the two mounting studs for the type FT projection case or by means of the four mounting holes on the flange for the semi-flush type FT case. Either of the studs or the mounting screws may be utilized for grounding the relay. The electrical connections may be made directly to the terminals by means of screws for steel panel mounting or to terminal studs furnished with the relay for thick panel mounting. The terminal studs may be easily removed or inserted by locking two nuts on the studs and then turning the proper nut with a wrench.

ADJUSTMENTS AND MAINTENANCE

The proper adjustments to insure correct operation of this relay have been made at the factory. Upon receipt of the relay, no customer adjustments, other than those covered under "SETTINGS", should be required.

ACCEPTANCE CHECK

The following check is recommended to insure that the relay is in proper working order:

A. OVERCURRENT UNIT (CO)

The directional unit contacts must be in the closed position when checking the operation of the overcurrent unit.

1. Contacts — By turning the time dial, move the moving contacts until they deflect the stationary contact to a position where the stationary contact is just resting against its backstop. The index mark located on the movement frame should coincide with the "0" mark on the time dial.

* For double trip relays, the follow on the stationary contacts should be approximately 1/64".

2. Minimum Trip Current — Set the time dial to position 6. Alternately apply tap value current plus 3% and tap value current minus 3%. The moving contact should leave the backstop at tap value current plus 3% and should return to the backstop at tap value

current minus 3%.

3. Time Curve — Table 1 shows the time curve calibration points for the various types of relays. With the time dial set to the indicated position, apply the currents specified by Table 1 (e.g. for the COV-8, 2 and 20 times tap value current) and measure the operating time of the relay. The operating times should equal those of Table 1 plus or minus 5 percent.

B. INDICATING CONTACTOR SWITCH (ICS) — Close the main relay contacts and pass sufficient d-c current through the trip circuit to close the contacts of the ICS. This value of current should not be greater than the particular ICS tap setting being used. The indicator target should drop freely.

C. INDICATING INSTANTANEOUS TRIP UNIT (IIT) — The core screw which is adjustable from the top of the trip unit determines the pickup value. The trip unit has a nominal ratio of adjustment of 1 to 4 and an accuracy within the limits of 10%.

Apply sufficient current to operate the IIT. The indicator target should drop freely.

D. VOLTAGE UNIT (V)

1. Contact Gap — The gap between the stationary contact and moving contact with the relay in a de-energized position should be approximately .020".

2. Sensitivity — The contacts should close when voltage is reduced to approximately 80 volts.

ROUTINE MAINTENANCE

All relays should be inspected periodically and the time of operation should be checked at least once every year or at such other time intervals as may be dictated by experience to be suitable to the particular application. Phantom loads should not be used in testing induction-type relays because of the resulting distorted current wave form which produces an error in timing.

All contacts should be periodically cleaned. A contact burnisher S#182A836H01 is recommended for this purpose. The use of abrasive material for cleaning contacts is not recommended, because of the danger of embedding small particles in the face of the soft silver and thus impairing the contact.

CALIBRATION

Use the following procedure for calibrating the relay if the relay has been taken apart for repairs or the adjustments have been disturbed. This procedure should not be used unless it is apparent that the relay is not in proper working order. (See "Acceptance Check").

A. OVERCURRENT UNIT (CO)

1. Contacts — By turning the time dial move the moving contacts until they deflect the stationary contact to a position where the stationary contact is just resting against its backstop. The index mark

located on the movement frame should coincide with the "0" mark on the time dial.

- * For double trip relays only, the follow on the stationary contacts is obtained through the use of the stationary contact adjusting screw. The upper stationary contact is adjusted first such that there is approximately 1/64" follow. The lower stationary contact is then adjusted such that both stationary contacts make contact simultaneously with their respective moving contact.

2. Minimum Trip Current — The adjustment of the spring tension in setting the minimum trip current value of the relay is most conveniently made with the damping magnet removed.

With the time dial set on "0", wind up the spiral spring by means of the spring adjuster until approximately 6-3/4 convolutions show.

Set the relay on the minimum tap setting, the time dial to position 6.

Adjust the control spring tension so that the moving contact will leave the backstop at tap value current + 1.0% and will return to the backstop at tap value current - 1.0%.

3. Time Curve Calibration - Install the permanent magnet.

Apply the indicated current per Table 1 for the permanent magnet adjustment (e.g. COV-8, 2 times tap value) and measure the operating time. Adjust the permanent magnet keeper until the operating time corresponds to the value of Table 1.

Apply the indicated current per Table 1 for the electromagnet plug adjustment (e.g. COV-8, 20 times tap value) and measure the operating time. Adjust the proper plug until the operating time corresponds to the value in Table 1. (Withdrawing the left-hand plug, front view, increases the operating time and withdrawing the right-hand plug, front view, decreases the time.) In adjusting the plugs, one plug should be screwed in completely and the other plug run in or out until the proper operating time has been obtained.

Recheck the permanent magnet adjustment. If the operating time for this calibration point has changed, readjust the permanent magnet and then recheck the electromagnet plug adjustment.

B. INDICATING CONTACTOR SWITCH — UNIT (ICS)

Close the main relay contacts and pass sufficient d-c current through the trip circuit to close the contacts of the ICS. This value of current should be not

greater than the particular ICS tap setting being used. The indicator target should drop freely.

C. INDICATING INSTANTANEOUS TRIP UNIT (IIT)

Since the minimum and maximum markings on the scale only indicate the working range of the core screw, the core screw must be adjusted to the value of pick-up current desired.

The nameplate data will furnish the actual current range that may be obtained from IIT unit.

D. VOLTAGE UNIT (V)

1. The upper pin bearing should be screwed down until there is approximately 1/64" clearance between it and the top of shaft bearing. The upper pin bearing should then be securely locked in position with the lock nut. The lower bearing position is fixed and cannot be adjusted.

2. The contact gap adjustment for the directional unit is made as follows:

With the moving contact in the normally-closed position, i.e. against the left stop on bridge, screw in the stationary contact until both contacts just close as indicated by a neon lamp in the contact circuit. Then, screw the stationary contact in towards the moving contact an additional one-half turn. The clamp holding the stationary contact housing need not be loosened for the adjustment since the clamp utilizes a spring-type action in holding the stationary contact in position.

3. The sensitivity adjustment is made in two steps.

A. The adjustable resistor, located at the rear of the voltage unit, is adjusted such that the maximum resistance is in the circuit (Approximately 2500 ohms).

B. The tension of the spiral spring, attached to the moving element assembly, is then varied. The spring is adjusted by placing a screwdriver or similar tool into one of the notches located on the periphery of the spring adjuster and rotating it. The spring adjuster is located on the underside of the bridge and is held in place by a spring type clamp that does not have to be loosened prior to making the necessary adjustments.

The spring is to be adjusted such that the contacts will close as indicated by a neon lamp in the contact circuit when the applied voltage is reduced to 80 volts. The contacts should open with 80 plus volts applied.


Any setting other than the 80 volts then can be made by adjusting the resistor for the desired contact closing voltage.

TABLE 1
TIME CURVE CALIBRATION DATA - 50-60 CYCLES FOR
OVERCURRENT UNIT

		Permanent Magnet Adjustment		Electromagnet Plug Adjustment	
Relay Type	Time Dial Position	Current (Multiples of Tap Value)	Operating Time (Seconds)	Current (Multiples of Tap Value)	Operating Time (Seconds)
6	6	2	2.46	20	1.19
7	6	2	4.27	20	1.11
8	6	2	13.35	20	1.11
9	6	2	8.87	20	0.65

RENEWAL PARTS

Repair work can be done most satisfactorily at the factory. However, interchangeable parts can be furnished to the customers who are equipped for doing repair work. When ordering parts, always give the complete nameplate data.



57-D-7901

Fig. 10. Outline and Drilling Plan for the Type COV Relay in Type FT21 Case.




WESTINGHOUSE ELECTRIC CORPORATION

METER DIVISION



NEWARK, N.J.

Printed in U. S. A.



INSTALLATION • OPERATION • MAINTENANCE I N S T R U C T I O N S

TYPE COV VOLTAGE CONTROLLED OVERCURRENT RELAY

CAUTION Before putting relays into service, remove all blocking which may have been inserted for the purpose of securing the parts during shipment, make sure that all moving parts operate freely, inspect the contacts to see that they are clean and close properly, and operate the relay to check the settings and electrical connections.

APPLICATION

The type COV relay is applicable where it is desired that an overcurrent unit be set to operate on less than full load current when the voltage falls below a predetermined value, and it is desired not to operate for any magnitude of current when the voltage is above the predetermined value. A typical application is overcurrent back-up protection on generators.

CONTENTS

This instruction leaflet applies to the following types of relays:

Type COV-6 Definite Minimum Time Relay		
Type COV-7 Moderately Inverse	"	"
Type COV-8 Inverse	"	"
Type COV-9 Very Inverse	"	"

* Type COV-11 Extremely Inverse " "

CONSTRUCTION AND OPERATION

The relay consists of an overcurrent unit, a voltage unit with adjustable resistor, an indicating contactor switch unit and an indicating instantaneous trip unit when required.

* A. OVERCURRENT UNIT (CO)

The electromagnets for the types COV-6, COV-7, COV-8 and COV-9 relays have a main tapped coil located on the center leg of an "E" type laminated structure that produces a flux which divides and returns through the outer legs. A shading coil causes the flux through the left leg to lag the main pole flux. The out-of-phase fluxes thus produced in the air gap cause a contact closing torque.

The electromagnet for the types COV-11 relay has a main coil consisting of a tapped primary winding. Two identical coils on the outer legs of the lamination structure are connected to the main coil secondary in

a manner so that the combination of all the fluxes produced by the electromagnet result in out-of-phase fluxes in the air gap. The out-of-phase air gap fluxes produced cause a contact closing torque.

B. INDICATING CONTACTOR SWITCH UNIT (ICS)

The indicating contactor switch is a small d-c operated clapper type device. A magnetic armature, to which leaf-spring mounted contacts are attached, is attracted to the magnetic core upon energization of the switch. When the switch closes, the moving contacts bridge two stationary contacts, completing the trip circuit. Also during this operation two fingers on the armature deflect a spring located on the front of the switch, which allows the operation indicator target to drop. The target is reset from the outside of the case by a push rod located at the bottom of the cover.

The front spring, in addition to holding the target, provides restraint for the armature and thus controls the pickup value of the switch.

C. INDICATING INSTANTANEOUS TRIP UNIT (IT)

The instantaneous trip unit is a small a-c operated clapper type device. A magnetic armature, to which leaf-spring mounted contacts are attached, is attracted to the magnetic core upon energization of the switch. When the switch closes, the moving contacts bridge two stationary contacts completing the trip circuit. Also during the operation two fingers on the armature deflect a spring located on the front of the switch which allows the operation indicator target to drop. The target is reset from the outside of the case by a push rod located at the bottom of the cover.

* A core screw accessible from the top of the switch provides the adjustable pickup range.

D. VOLTAGE UNIT (V)

The voltage unit is an induction cylinder type unit.

Mechanically, the voltage unit is composed of four basic components: A die-cast aluminum frame, an electromagnet, a moving element assembly, and a molded bridge.

The frame serves as the mounting structure for the magnetic core. The magnetic core which houses the lower pin bearing is secured to the frame by a locking





Fig. 1. Internal Schematic of the Type COV Relay in the Type FT21 Case.



* Fig. 2. Internal Schematic of the Type COV Relay with Indicating Instantaneous Trip Unit in the Type FT21 Case.

nut. The bearing can be replaced, if necessary, without having to remove the magnetic core from the frame.

The electromagnet has two pairs of voltage coils. Each pair of diametrically opposed coils is connected in series. In addition; one pair is in series with an adjustable resistor. These sets are paralleled as shown in Fig. 1. The adjustable resistor serves not only to shift the phase angle of the one flux with respect to the other to produce torque, but it also provides a dropout adjustment.

Locating pins in the electromagnet are used to accurately position the lower pin bearing, which is mounted on the frame, with respect to the upper pin bearing, which is threaded into the bridge. The electromagnet is secured to the frame by four mounting screws.

The moving element assembly consists of a spiral spring, contact carrying member, and an aluminum cylinder assembled to a molded hub which holds the shaft. The shaft has removable top and bottom jewel bearings. The shaft rides between the bottom pin bearing and the upper pin bearing with the cylinder rotating in an air gap formed by the electromagnet and the magnetic core. The stops for the moving element contact arm are an integral part of the bridge.

The bridge is secured to the electromagnet and frame by two mounting screws. In addition to holding the upper pin bearing, the bridge is used for mounting the adjustable stationary contact housing. The stationary contact housing is held in position by a spring type clamp. The spring adjuster is located on the underside of the bridge and is attached to the moving contact arm by a spiral spring. The spring adjuster is also held in place by a spring type clamp.

With the contacts closed, the electrical connection is made through the stationary contact housing clamp, to the moving contact, through the spiral spring out to the spring adjuster clamp.

CHARACTERISTICS

To prevent the relay from operating for currents above the overcurrent unit pick-up, the voltage unit contact is connected in the shading coil circuit of the overcurrent unit. The voltage contact is held open at voltages above the set point, to prevent torque from being produced in the overcurrent unit. This arrangement yields a tripping characteristic as shown in Fig. 3.

OVERCURRENT UNIT

The relays are generally available in the following overcurrent unit current ranges:

Range	Taps						
0.5 - 2.5	0.5	0.6	0.8	1.0	1.5	2.0	2.5
2 - 6	2	2.5	3	3.5	4	5	6
4 - 12	4	5	6	7	8	10	12

These relays may have either single or double circuit closing contacts for tripping either one or two circuit breakers.

The time vs. current characteristics are shown in Figs. 4 to 7. These characteristics give the contact closing time for the various time dial settings when the indicated multiples of tap value current are applied to the relay.

VOLTAGE UNIT

The contact can be adjusted to close over a range of 80 to 100 volts. The contact opens if the voltage is higher than the set value. The drop-out ratio of the unit is 98% or higher. Relays are shipped from the factory with a 90 volt setting.

TRIP CIRCUIT

The main contacts will safely close 30 amperes at 250 volts d-c and the seal-in contacts of the indicating contactor switch will safely carry this current long enough to trip a circuit breaker.

The indicating instantaneous trip contacts will safely close 30 amperes at 250 volts d-c, and will carry this current long enough to trip a breaker.

The indicating contactor switch has two taps that provide a pickup setting of 0.2 or 2 amperes. To change taps requires connecting the lead located in front of the tap block to the desired setting by means of a screw connection.

TRIP CIRCUIT CONSTANTS

Indicating Contactor Switch —

0.2 amp tap 6.5 ohms d-c resistance

2.0 amp tap 0.15 ohms d-c resistance




Fig. 3. Typical Tripping Characteristics of Type COV Relay.

ENERGY REQUIREMENTS

* VOLTAGE UNIT

<u>Frequency</u>	<u>Drop-Out Adjustment Volts</u>	<u>Maximum Volts Continuous</u>	<u>Volt-Ampere + Burden at 120 volts</u>	<u>Drop-Out Ratio</u>
60	80-100	132	8.0	98%

+ Volt-Ampere burden is average for the various settings.

COV-6 OVERCURRENT UNITS

VOLT AMPERES**

<u>Ampere Range</u>	<u>Tap</u>	<u>Continuous Rating (Amperes)</u>	<u>One Second Rating * (Amperes)</u>	<u>Power Factor Angle ϕ</u>	<u>At Tap Value Current</u>	<u>At 3 Times Tap Value Current</u>	<u>At 10 Times Tap Value Current</u>	<u>At 20 Times Tap Value Current</u>
0.5/2.5	(0.5	2.7	88	69	3.92	20.6	103	270
	(0.6	3.1	88	68	3.96	20.7	106	288
	(0.8	3.7	88	67	3.96	21	114	325
	(1.0	4.1	88	66	4.07	21.4	122	360
	(1.5	5.7	88	62	4.19	23.2	147	462
	(2.0	6.8	88	60	4.30	24.9	168	548
	(2.5	7.7	88	58	4.37	26.2	180	630
2/6	(2	8	230	67	3.88	21	110	308
	(2.5	8.8	230	66	* 3.90	21.6	118	342
	(3	9.7	230	64	3.93	22.1	126	381
	(3.5	10.4	230	63	4.09	23.1	136	417
	(4	11.2	230	62	* 4.12	23.5	144	448
	(5	12.5	230	59	4.20	24.8	162	540
	(6	13.7	230	57	4.38	26.5	183	624
4/12	(4	16	460	65	4.00	22.4	126	376
	(5	18.8	460	63	4.15	23.7	143	450
	(6	19.3	460	61	4.32	25.3	162	531
	(7	20.8	460	59	* 4.37	26.4	183	611
	(8	22.5	460	56	4.40	27.8	204	699
	(10	25	460	53	4.60	30.1	247	880
	(12	28	460	47	4.92	35.6	288	1056

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.

ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.

ENERGY REQUIREMENTS

COV-7 OVERCURRENT UNITS

		<u>VOLT AMPERES**</u>						
Ampere Range	Tap	Continuous Rating (Amperes)	One Second Rating* (Amperes)	Power Factor Angle ϕ	At Tap Value Current	At 3 Times Tap Value Current	At 10 Times Tap Value Current	At 20 Times Tap Value Current
0.5/2.5	(0.5	2.7	88	68	3.88	20.7	103	278
	(0.6	3.1	88	67	3.93	20.9	107	288
	(0.8	3.7	88	66	3.93	21.1	114	320
	(1.0	4.1	88	64	4.00	21.6	122	356
	(1.5	5.7	88	61	4.08	22.9	148	459
	(2.0	6.8	88	58	4.24	24.8	174	552
	(2.5	7.7	88	56	4.38	25.9	185	640
2/6	(2	8	230	66	4.06	21.3	111	306
	(2.5	8.8	230	63	4.07	21.8	120	342
	(3	9.7	230	63	4.14	22.5	129	366
	(3.5	10.4	230	62	4.34	23.4	141	413
	(4	11.2	230	61	4.34	23.8	149	448
	(5	12.5	230	59	4.40	25.2	163	530
	(6	13.7	230	58	4.62	27	183	624
4/12	(4	16	460	64	4.24	22.8	129	392
	(5	18.8	460	61	4.30	24.2	149	460
	(6	19.3	460	60	4.62	25.9	168	540
	(7	20.8	460	58	4.69	27.3	187	626
	(8	22.5	460	55	4.80	29.8	211	688
	(10	25	460	51	5.20	33	260	860
	(12	28	460	46	5.40	37.5	308	1032

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.

ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.

TYPE COV RELAY

* ENERGY REQUIREMENTS

COV-8 INVERSE TIME AND COV-9 VERY INVERSE TIME RELAYS

AMPERE RANGE	TAP	CONTINUOUS RATING (AMPERES)	ONE SECOND RATING* (AMPERES)	POWER FACTOR ANGLE ϕ	VOLT AMPERES**			
					AT TAP VALUE CURRENT	AT 3 TIMES TAP VALUE CURRENT	AT 10 TIMES TAP VALUE CURRENT	AT 20 TIMES TAP VALUE CURRENT
0.5/2.5	(0.5	2.7	88	72	2.38	21	132	350
	(0.6	3.1	88	71	2.38	21	134	365
	(0.8	3.7	88	69	2.40	21.1	142	400
	(1.0	4.1	88	67	2.42	21.2	150	440
	(1.5	5.7	88	62	2.51	22	170	530
	(2.0	6.8	88	57	2.65	23.5	200	675
	(2.5	7.7	88	53	2.74	24.8	228	800
2/6	(2	8	230	70	2.38	21	136	360
	(2.5	8.8	230	66	2.40	21.1	142	395
	(3	9.7	230	64	2.42	21.5	149	430
	(3.5	10.4	230	62	2.48	22	157	470
	(4	11.2	230	60	2.53	22.7	164	500
	(5	12.5	230	58	2.64	24	180	580
	(6	13.7	230	56	2.75	25.2	198	660
4/12	(4	16	460	68	2.38	21.3	146	420
	(5	18.8	460	63	2.46	21.8	158	480
	(6	19.3	460	60	2.54	22.6	172	550
	(7	20.8	460	57	2.62	23.6	190	620
	(8	22.5	460	54	2.73	24.8	207	700
	(10	25	460	48	3.00	27.8	248	850
	(12	28	460	45	3.46	31.4	292	1020

TYPE COV-11 RELAY

AMPERE RANGE	TAP	CONTINUOUS RATING (AMPERES)	ONE SECOND RATING* (AMPERES)	POWER FACTOR ANGLE ϕ	VOLT AMPERES**			
					AT TAP VALUE CURRENT	AT 3 TIMES TAP VALUE CURRENT	AT 10 TIMES TAP VALUE CURRENT	AT 20 TIMES TAP VALUE CURRENT
0.5/2.5	0.5	1.7	88	36	0.72	6.54	71.8	250
	0.6	1.9	88	34	0.75	6.80	75.0	267
	0.8	2.2	88	30	0.81	7.46	84.0	298
	1.0	2.5	88	27	0.89	8.30	93.1	330
	1.5	3.0	88	22	1.13	10.04	115.5	411
	2.0	3.5	88	17	1.30	11.95	136.3	502
	2.5	3.8	88	16	1.48	13.95	160.0	610
2/6	2.0	7.0	230	32	0.73	6.30	74.0	264
	2.5	7.8	230	30	0.78	7.00	78.5	285
	3.0	8.3	230	27	0.83	7.74	84.0	309
	3.5	9.0	230	24	0.88	8.20	89.0	340
	4.0	10.0	230	23	0.96	9.12	102.0	372
	5.0	11.0	230	20	1.07	9.80	109.0	430
	6.0	12.0	230	20	1.23	11.34	129.0	504
4/12	4.0	14	460	29	0.79	7.08	78.4	296
	5.0	16	460	25	0.89	8.00	90.0	340
	6.0	17	460	22	1.02	9.18	101.4	378
	7.0	18	460	20	1.10	10.00	110.0	454
	8.0	20	460	18	1.23	11.1	124.8	480
	10.0	22	460	17	1.32	14.9	131.6	600
	12.0	26	460	16	1.8	16.3	180.0	720

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.

ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.






Fig. 4. Typical 50 and 60 Cycle Time Curves of COV-6 Overcurrent Unit.




418247

Fig. 5. Typical 50 and 60 Cycle Time Curves of COV-7 Overcurrent Unit.




418248

Fig. 6. Typical 50 and 60 Cycle Time Curves of COV-8 Overcurrent Unit.



418249

Fig. 7. Typical 50 and 60 Cycle Time Curves of COV-9 Overcurrent Unit.



288B655
TYPICAL TIME CURVES
TYPE CO-11
OVER CURRENT RELAY
50-60 CYCLES

* Fig. 8. Typical Time Curves of the Type COV-11 Overcurrent Unit.

TYPE COV RELAY

CALIBRATION

Use the following procedure for calibrating the relay if the relay has been taken apart for repairs or the adjustments have been disturbed. This procedure should not be used unless it is apparent that the relay is not in proper working order. (See "Acceptance Check").

A. OVERCURRENT UNIT (CO)

1. Contact

- a) By turning the time dial, move the moving contacts until they deflect the stationary contact to a position where the stationary contact is resting against its backstop. The index mark located on the movement frame should coincide with the "O" mark on the time dial. For double trip relays, the follow on the stationary contacts should be approximately $1/64''$.
- b) For relays identified with a "T", located at lower left of stationary contact block, the index mark on the movement frame will coincide with the "O" mark on the time dial when the stationary contact has moved through approximately one-half of its normal deflection. Therefore, with the stationary contact resting against the backstop, the index mark is offset to the right of the "O" mark by approximately $.020''$. The placement of the various time dial positions in line with the index mark will give operating times as shown on the respective time-current curves. For double trip relays, the follow on the stationary contacts should be approximately $1/32''$.

2. Minimum Trip Current — The adjustment of the spring tension in setting the minimum trip current value of the relay is most conveniently made with the damping magnet removed.

With the time dial set on "0", wind up the spiral spring by means of the spring adjuster until approximately $6-3/4$ convolutions show.

Set the relay on the minimum tap setting, the time dial to position 6.

Adjust the control spring tension so that the moving contact will leave the backstop at tap value current + 1.0% and will return to the backstop at tap value current - 1.0%.

3. Time Curve Calibration - Install the permanent magnet.

Apply the indicated current per Table 1 for the permanent magnet adjustment (e.g. COV-8, 2 times tap value) and measure the operating time. Adjust the permanent magnet keeper until the operating time corresponds to the value of Table 1.

Apply the indicated current per Table 1 for the electromagnet plug adjustment (e.g. COV-8, 20 times tap value) and measure the operating time. Adjust

the proper plug until the operating time corresponds to the value in Table 1. (Withdrawing the left-hand plug, front view, increases the operating time and withdrawing the right-hand plug, front view, decreases the time.) In adjusting the plugs, one plug should be screwed in completely and the other plug run in or out until the proper operating time has been obtained.

Recheck the permanent magnet adjustment. If the operating time for this calibration point has changed, readjust the permanent magnet and then recheck the electromagnet plug adjustment.

B. INDICATING CONTACTOR SWITCH — UNIT (ICS)

Close the main relay contacts and pass sufficient d-c current through the trip circuit to close the contacts of the ICS. This value of current should be not greater than the particular ICS tap setting being used. The indicator target should drop freely.

C. INDICATING INSTANTANEOUS TRIP UNIT (IIT)

The core screw must be adjusted to the value of pick-up current desired.

The nameplate data will furnish the actual current range that may be obtained from IIT unit.

D. VOLTAGE UNIT (V)

1. The upper pin bearing should be screwed down until there is approximately $.025''$ clearance between it and the top of shaft bearing. The upper pin bearing should then be securely locked in position with the lock nut. The lower bearing position is fixed and cannot be adjusted.

2. The contact gap adjustment for the directional unit is made as follows:

With the moving contact in the normally-closed position, i.e. against the left stop on bridge, screw in the stationary contact until both contacts just close as indicated by a neon lamp in the contact circuit. Then, screw the stationary contact in towards the moving contact an additional one-half turn. The clamp holding the stationary contact housing need not be loosened for the adjustment since the clamp utilizes a spring-type action in holding the stationary contact in position.

3. The sensitivity adjustment is made in two steps.

A. The adjustable resistor, located at the rear of the voltage unit, is adjusted such that the maximum resistance is in the circuit (Approximately 2500 ohms).

B. The tension of the spiral spring, attached to the moving element assembly, is then varied. The spring is adjusted by placing a screwdriver or similar tool into one of the notches located on the periphery of the spring adjuster and rotating it. The spring adjuster is located on the underside of the bridge and

TABLE 1
TIME CURVE CALIBRATION DATA - 50-60 CYCLES FOR
OVERCURRENT UNIT

Relay Type	Time Dial Position	Permanent Magnet Adjustment		Electromagnet Plug Adjustment	
		Current (Multiples of Tap Value)	Operating Time (Seconds)	Current (Multiples of Tap Value)	Operating Time (Seconds)
6	6	2	2.46	20	1.19
7	6	2	4.27	20	1.11
8	6	2	13.35	20	1.11
9	6	2	8.87	20	0.65
* 11	6	2	11.27	20	0.24 Δ

Δ For 50 cycle COV-11 relay, 20 times operating time limits are 0.24 + 10%, -5%.

is held in place by a spring type clamp that does not have to be loosened prior to making the necessary adjustments.


The spring is to be adjusted such that the contacts will close as indicated by a neon lamp in the contact circuit when the applied voltage is reduced to 80 volts. The contacts should open with 80 plus volts applied.

Any setting other than the 80 volts then can be

made by adjusting the resistor for the desired contact closing voltage.

RENEWAL PARTS

Repair work can be done most satisfactorily at the factory. However, interchangeable parts can be furnished to the customers who are equipped for doing repair work. When ordering parts, always give the complete nameplate data.




57-D - 7901

* Fig. 11. Outline and Drilling Plan for the Type COV Relay in Type FT21 Case.

WESTINGHOUSE ELECTRIC CORPORATION
RELAY DEPARTMENT **NEWARK, N. J.**

Printed in U. S. A.



INSTALLATION • OPERATION • MAINTENANCE I N S T R U C T I O N S

TYPE COV VOLTAGE CONTROLLED OVERCURRENT RELAY

CAUTION Before putting relays into service, remove all blocking which may have been inserted for the purpose of securing the parts during shipment, make sure that all moving parts operate freely, inspect the contacts to see that they are clean and close properly, and operate the relay to check the settings and electrical connections.

APPLICATION

The type COV relay is applicable where it is desired that an overcurrent unit be set to operate on less than full load current when the voltage falls below a predetermined value, and it is desired not to operate for any magnitude of current when the voltage is above the predetermined value. A typical application is overcurrent back-up protection on generators.

CONTENTS

This instruction leaflet applies to the following types of relays:

Type COV-6 Definite Minimum Time Relay		
Type COV-7 Moderately Inverse	"	"
Type COV-8 Inverse	"	"
Type COV-9 Very Inverse	"	"
Type COV-11 Extremely Inverse	"	"

CONSTRUCTION AND OPERATION

The relay consists of an overcurrent unit, a voltage unit with adjustable resistor, an indicating contactor switch unit and an indicating instantaneous trip unit when required.

A. OVERCURRENT UNIT (CO)

The electromagnets for the types COV-6, COV-7, COV-8 and COV-9 relays have a main tapped coil located on the center leg of an "E" type laminated structure that produces a flux which divides and returns through the outer legs. A shading coil causes the flux through the left leg to lag the main pole flux. The out-of-phase fluxes thus produced in the air gap cause a contact closing torque.

The electromagnet for the types COV-11 relay has a main coil consisting of a tapped primary winding. Two identical coils on the outer legs of the lamination structure are connected to the main coil secondary in

a manner so that the combination of all the fluxes produced by the electromagnet result in out-of-phase fluxes in the air gap. The out-of-phase air gap fluxes produced cause a contact closing torque.

B. INDICATING CONTACTOR SWITCH UNIT (ICS)

The indicating contactor switch is a small d-c operated clapper type device. A magnetic armature, to which leaf-spring mounted contacts are attached, is attracted to the magnetic core upon energization of the switch. When the switch closes, the moving contacts bridge two stationary contacts, completing the trip circuit. Also during this operation two fingers on the armature deflect a spring located on the front of the switch, which allows the operation indicator target to drop. The target is reset from the outside of the case by a push rod located at the bottom of the cover.

The front spring, in addition to holding the target, provides restraint for the armature and thus controls the pickup value of the switch.

C. INDICATING INSTANTANEOUS TRIP UNIT (IIT)

The instantaneous trip unit is a small a-c operated clapper type device. A magnetic armature, to which leaf-spring mounted contacts are attached, is attracted to the magnetic core upon energization of the switch. When the switch closes, the moving contacts bridge two stationary contacts completing the trip circuit. Also during the operation two fingers on the armature deflect a spring located on the front of the switch which allows the operation indicator target to drop. The target is reset from the outside of the case by a push rod located at the bottom of the cover.

A core screw accessible from the top of the switch provides the adjustable pickup range.

D. VOLTAGE UNIT (V)

The voltage unit is an induction cylinder type unit.

Mechanically, the voltage unit is composed of four basic components: A die-cast aluminum frame, an electromagnet, a moving element assembly, and a molded bridge.

The frame serves as the mounting structure for the magnetic core. The magnetic core which houses the lower pin bearing is secured to the frame by a locking




Fig. 1. Internal Schematic of the Type COV Relay in the Type FT21 Case.

nut. The bearing can be replaced, if necessary, without having to remove the magnetic core from the frame.

The electromagnet has two pairs of voltage coils. Each pair of diametrically opposed coils is connected in series. In addition; one pair is in series with an adjustable resistor. These sets are paralleled as shown in Fig. 1. The adjustable resistor serves not only to shift the phase angle of the one flux with respect to the other to produce torque, but it also provides a dropout adjustment.

Locating pins in the electromagnet are used to accurately position the lower pin bearing, which is mounted on the frame, with respect to the upper pin bearing, which is threaded into the bridge. The electromagnet is secured to the frame by four mounting screws.

The moving element assembly consists of a spiral spring, contact carrying member, and an aluminum cylinder assembled to a molded hub which holds the shaft. The shaft rides between the bottom pin bearing and the upper pin bearing with the cylinder rotating in an air gap formed by the electromagnet and the magnetic core. The stops for the moving element contact arm are an integral part of the bridge.

The bridge is secured to the electromagnet and frame by two mounting screws. In addition to holding the upper pin bearing, the bridge is used for mounting the adjustable stationary contact housing. The stationary contact housing is held in position by a spring type clamp. The spring adjuster is located on the underside of the bridge and is attached to the moving contact arm by a spiral spring. The spring adjuster is also held in place by a spring type clamp.




Fig. 2. Internal Schematic of the Type COV Relay with Indicating Instantaneous Trip Unit in the Type FT21 Case.

With the contacts closed, the electrical connection is made through the stationary contact housing clamp, to the moving contact, through the spiral spring out to the spring adjuster clamp.

CHARACTERISTICS

To prevent the relay from operating for currents above the overcurrent unit pick-up, the voltage unit contact is connected in the shading coil circuit of the overcurrent unit. The voltage contact is held open at voltages above the set point, to prevent torque from being produced in the overcurrent unit. This arrangement yields a tripping characteristic as shown in Fig. 3.

OVERCURRENT UNIT

The relays are generally available in the following overcurrent unit current ranges:

Range	Taps						
0.5 — 2.5	0.5	0.6	0.8	1.0	1.5	2.0	2.5
2 — 6	2	2.5	3	3.5	4	5	6
4 — 12	4	5	6	7	8	10	12

These relays may have either single or double circuit closing contacts for tripping either one or two circuit breakers.

The time vs. current characteristics are shown in * Figs. 4 to 8. These characteristics give the contact closing time for the various time dial settings when the indicated multiples of tap value current are applied to the relay.

VOLTAGE UNIT

The contact can be adjusted to close over a range of 80 to 100 volts. The contact opens if the voltage is higher than the set value. The drop-out ratio of the unit is 98% or higher. Relays are shipped from the factory with a 90 volt setting.

TRIP CIRCUIT

The main contacts will safely close 30 amperes at 250 volts d-c and the seal-in contacts of the indicating contactor switch will safely carry this current long enough to trip a circuit breaker.

The indicating instantaneous trip contacts will safely close 30 amperes at 250 volts d-c, and will carry this current long enough to trip a breaker.

The indicating contactor switch has two taps that provide a pickup setting of 0.2 or 2 amperes. To change taps requires connecting the lead located in front of the tap block to the desired setting by means of a screw connection.

TRIP CIRCUIT CONSTANTS

Indicating Contactor Switch —
 0.2 amp tap 6.5 ohms d-c resistance
 2.0 amp tap 0.15 ohms d-c resistance




Fig. 3. Typical Tripping Characteristics of Type COV Relay.

ENERGY REQUIREMENTS

Frequency	Drop-Out Adjustment Volts	VOLTAGE UNIT		Drop-Out Ratio
		Maximum Volts Continuous	Volt-Ampere + Burden at 120 volts	
60	80-100	132	8.0	98%

+ Volt-Ampere burden is average for the various settings.

COV-6 OVERCURRENT UNITS

Ampere Range		VOLT AMPERES**						
		Continuous Rating (Amperes)	One Second Rating * (Amperes)	Power Factor Angle ϕ	At Tap Value Current	At 3 Times Tap Value Current	At 10 Times Tap Value Current	At 20 Times Tap Value Current
0.5/2.5	(0.5	2.7	88	69	3.92	20.6	103	270
	(0.6	3.1	88	68	3.96	20.7	106	288
	(0.8	3.7	88	67	3.96	21	114	325
	(1.0	4.1	88	66	4.07	21.4	122	360
	(1.5	5.7	88	62	4.19	23.2	147	462
	(2.0	6.8	88	60	4.30	24.9	168	548
	(2.5	7.7	88	58	4.37	26.2	180	630
2/6	(2	8	230	67	3.88	21	110	308
	(2.5	8.8	230	66	3.90	21.6	118	342
	(3	9.7	230	64	3.93	22.1	126	381
	(3.5	10.4	230	63	4.09	23.1	136	417
	(4	11.2	230	62	4.12	23.5	144	448
	(5	12.5	230	59	4.20	24.8	162	540
	(6	13.7	230	57	4.38	26.5	183	624
4/12	(4	16	460	65	4.00	22.4	126	376
	(5	18.8	460	63	4.15	23.7	143	450
	(6	19.3	460	61	4.32	25.3	162	531
	(7	20.8	460	59	4.37	26.4	183	611
	(8	22.5	460	56	4.40	27.8	204	699
	(10	25	460	53	4.60	30.1	247	880
	(12	28	460	47	4.92	35.6	288	1056

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.

ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.

ENERGY REQUIREMENTS

COV-7 OVERCURRENT UNITS

		VOLT AMPERES**						
Ampere Range	Tap	Continuous Rating (Amperes)	One Second Rating* (Amperes)	Power Factor Angle ϕ	At Tap Value Current	At 3 Times Tap Value Current	At 10 Times Tap Value Current	At 20 Times Tap Value Current
0.5/2.5	(0.5	2.7	88	68	3.88	20.7	103	278
	(0.6	3.1	88	67	3.93	20.9	107	288
	(0.8	3.7	88	66	3.93	21.1	114	320
	(1.0	4.1	88	64	4.00	21.6	122	356
	(1.5	5.7	88	61	4.08	22.9	148	459
	(2.0	6.8	88	58	4.24	24.8	174	552
	(2.5	7.7	88	56	4.38	25.9	185	640
2/6	(2	8	230	66	4.06	21.3	111	306
	(2.5	8.8	230	63	4.07	21.8	120	342
	(3	9.7	230	63	4.14	22.5	129	366
	(3.5	10.4	230	62	4.34	23.4	141	413
	(4	11.2	230	61	4.34	23.8	149	448
	(5	12.5	230	59	4.40	25.2	163	530
	(6	13.7	230	58	4.62	27	183	624
4/12	(4	16	460	64	4.24	22.8	129	392
	(5	18.8	460	61	4.30	24.2	149	460
	(6	19.3	460	60	4.62	25.9	168	540
	(7	20.8	460	58	4.69	27.3	187	626
	(8	22.5	460	55	4.80	29.8	211	688
	(10	25	460	51	5.20	33	260	860
	(12	28	460	46	5.40	37.5	308	1032

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.

ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.

TYPE COV RELAY

ENERGY REQUIREMENTS

COV-8 INVERSE TIME AND COV-9 VERY INVERSE TIME RELAYS

AMPERE RANGE	TAP	CONTINUOUS RATING (AMPERES)	ONE SECOND RATING* (AMPERES)	POWER FACTOR ANGLE ϕ	VOLT AMPERES**			
					AT TAP VALUE CURRENT	AT 3 TIMES TAP VALUE CURRENT	AT 10 TIMES TAP VALUE CURRENT	AT 20 TIMES TAP VALUE CURRENT
0.5/2.5	(0.5	2.7	88	72	2.38	21	132	350
	0.6	3.1	88	71	2.38	21	134	365
	0.8	3.7	88	69	2.40	21.1	142	400
	1.0	4.1	88	67	2.42	21.2	150	440
	1.5	5.7	88	62	2.51	22	170	530
	2.0	6.8	88	57	2.65	23.5	200	675
	2.5	7.7	88	53	2.74	24.8	228	800
2/6	(2	8	230	70	2.38	21	136	360
	2.5	8.8	230	66	2.40	21.1	142	395
	3	9.7	230	64	2.42	21.5	149	430
	3.5	10.4	230	62	2.48	22	157	470
	4	11.2	230	60	2.53	22.7	164	500
	5	12.5	230	58	2.64	24	180	580
	6	13.7	230	56	2.75	25.2	198	660
4/12	(4	16	460	68	2.38	21.3	146	420
	5	18.8	460	63	2.46	21.8	158	480
	6	19.3	460	60	2.54	22.6	172	550
	7	20.8	460	57	2.62	23.6	190	620
	8	22.5	460	54	2.73	24.8	207	700
	10	25	460	48	3.00	27.8	248	850
	12	28	460	45	3.46	31.4	292	1020


TYPE COV-11 RELAY

AMPERE RANGE	TAP	CONTINUOUS RATING (AMPERES)	ONE SECOND RATING* (AMPERES)	POWER FACTOR ANGLE ϕ	VOLT AMPERES**			
					AT TAP VALUE CURRENT	AT 3 TIMES TAP VALUE CURRENT	AT 10 TIMES TAP VALUE CURRENT	AT 20 TIMES TAP VALUE CURRENT
0.5/2.5	0.5	1.7	88	36	0.72	6.54	71.8	250
	0.6	1.9	88	34	0.75	6.80	75.0	267
	0.8	2.2	88	30	0.81	7.46	84.0	298
	1.0	2.5	88	27	0.89	8.30	93.1	330
	1.5	3.0	88	22	1.13	10.04	115.5	411
	2.0	3.5	88	17	1.30	11.95	136.3	502
	2.5	3.8	88	16	1.48	13.95	160.0	610
2/6	2.0	7.0	230	32	0.73	6.30	74.0	264
	2.5	7.8	230	30	0.78	7.00	78.5	285
	3.0	8.3	230	27	0.83	7.74	84.0	309
	3.5	9.0	230	24	0.88	8.20	89.0	340
	4.0	10.0	230	23	0.96	9.12	102.0	372
	5.0	11.0	230	20	1.07	9.80	109.0	430
	6.0	12.0	230	20	1.23	11.34	129.0	504
4/12	4.0	14	460	29	0.79	7.08	78.4	296
	5.0	16	460	25	0.89	8.00	90.0	340
	6.0	17	460	22	1.02	9.18	101.4	378
	7.0	18	460	20	1.10	10.00	110.0	454
	8.0	20	460	18	1.23	11.1	124.8	480
	10.0	22	460	17	1.32	14.9	131.6	600
	12.0	26	460	16	1.8	16.3	180.0	720

* Thermal capacities for short times other than one second may be calculated on the basis of time being inversely proportional to the square of the current.


ϕ Degrees current lags voltage at tap value current.

** Voltages taken with Rectox type voltmeter.




418246

Fig. 4. Typical 50 and 60 Cycle Time Curves of COV-6 Overcurrent Unit.




418247

Fig. 5. Typical 50 and 60 Cycle Time Curves of COV-7 Overcurrent Unit.




418248

Fig. 6. Typical 50 and 60 Cycle Time Curves of COV-8 Overcurrent Unit.



418249

Fig. 7. Typical 50 and 60 Cycle Time Curves of COV-9 Overcurrent Unit.



288B655
TYPICAL TIME CURVES
TYPE CO-11
OVER CURRENT RELAY
50-60 CYCLES

TIME DIAL
SETTING

Fig. 8. Typical Time Curves of the Type COV-11 Overcurrent Unit.




Fig. 9. Diagram of Test Connections of the Overcurrent Unit.

SETTINGS

A. OVERCURRENT UNIT (CO)

The overcurrent unit settings can be defined either by tap settings and time dial position or by tap setting and a specific time of operation at some current multiple of the tap setting (e.g. 4 tap setting, 2 time dial position or 4 tap setting, 0.6 seconds at 6 times tap value current).

To provide selective circuit breaker operation, a minimum coordinating time of 0.3 seconds plus breaker time is recommended between the relay being set and the relays with which coordination is to be effected.

The connector screw on the terminal plate above the time dial makes connections to various turns on the operating coil. By placing this screw in the various terminal plate holes, the relay will respond to multiples of tap value currents in accordance with the various typical time-current curves.

CAUTION

Since the tap block connector screw carries operating current, be sure that the screw is turned tight. In order to avoid opening the current transformer circuits when changing taps under load, connect the spare tap screw in the desired tap position before removing the other tap screw from the original tap position.

INSTANTANEOUS RECLOSING

The factory adjustment of the CO unit contacts provides a contact follow. Where circuit breaker reclosing will be initiated immediately after a trip by




Fig. 10. External Schematic of the Type COV Relay on a Generator.

the CO contact, the time of the opening of the contacts should be a minimum. This condition is obtained by loosening the stationary contact mounting screw, removing the contact plate and then replacing the plate with the bent end resting against the contact spring.

For double trip relays, the upper stationary contact is adjusted such that the contact spring rests solidly against the back stop. The lower stationary contact is then adjusted such that both stationary contacts make contact simultaneously with their respective moving contact.

* B. INDICATING CONTACTOR SWITCH (ICS)

The only setting required on the ICS unit is the selection of the 0.2 to 2.0 ampere tap setting. This selection is made by connecting the lead located in front of the tap block to the desired setting by means of the connecting screw.

C. INDICATING INSTANTANEOUS TRIP (IIT)

The core screw must be adjusted to the value of pick-up desired.

The nameplate data will furnish the actual current range that may be obtained from IIT unit.

D. VOLTAGE UNIT (V)

The voltage unit is calibrated to close its contact when the applied voltage is reduced to 80 volts. The voltage unit can be set to close its contacts from 80 volts to 100 volts by adjusting the resistor located at the rear of the voltage unit. The spiral spring is not disturbed when making any setting other than the calibrated setting of 80 volts.

INSTALLATION

The relays should be mounted on switchboard panels or their equivalent in a location free from dirt, moisture, excessive vibration and heat. Mount the relay vertically by means of the two mounting studs for the projection mounting or by means of the four mounting holes on the flange for the semi-flush mounting. Either of the studs or the mounting screws may be utilized for grounding the relay. The electrical connections may be made directly to the terminals by means of screws for steel panel mounting or to terminal studs furnished with the relay for thick panel mounting. The terminal studs may be easily removed or inserted by locking two nuts on the studs and then turning the proper nut with a wrench.

ADJUSTMENTS AND MAINTENANCE

The proper adjustments to insure correct operation of this relay have been made at the factory. Upon receipt of the relay, no customer adjustments, other than those covered under "SETTINGS", should be required.

ACCEPTANCE CHECK

The following check is recommended to insure that the relay is in proper working order:

A. OVERCURRENT UNIT (CO)

The directional unit contacts must be in the closed position when checking the operation of the overcurrent unit.

1. Contact

- a) By turning the time dial, move the moving contacts until they deflect the stationary contact to a position where the stationary contact is resting against its backstop. The index mark located on the movement frame should coincide with the "O" mark on the time dial. For double trip relays, the follow on the stationary contacts should be approximately $1/64''$.
- b) For relays identified with a "T", located at lower left of stationary contact block, the index mark on the movement frame will coincide with the "O" mark on the time dial when the stationary contact has moved through approximately

one-half of its normal deflection. Therefore, with the stationary contact resting against the backstop, the index mark is offset to the right of the "O" mark by approximately $.020''$. The placement of the various time dial positions in line with the index mark will give operating times as shown on the respective time-current curves. For double trip relays, the follow on the stationary contacts should be approximately $1/32''$.

2. Minimum Trip Current – Set the time dial to position 6. Alternately apply tap value current plus 3% and tap value current minus 3%. The moving contact should leave the backstop at tap value current plus 3% and should return to the backstop at tap value current minus 3%.

3. Time Curve – Table 1 shows the time curve calibration points for the various types of relays. With the time dial set to the indicated position, apply the currents specified by Table 1 (e.g. for the COV-8, 2 and 20 times tap value current) and measure the operating time of the relay. The operating times should equal those of Table 1 plus or minus 5 percent.

* For type CO-11 relay only, the 1.30 times tap value operating time from the number 6 time dial position is $54.8 \pm 5\%$ seconds and should be checked first. It is important that the 1.30 times tap value current be maintained accurately. The maintaining of this current accurately is necessary because of the steepness of the slope of the time-current characteristic (Figure 8). A 1% variation in the 1.30 times tap value current (including measuring instrument deviation) will change the nominal operating time by approximately 4%.

Table I shows the time curve calibration points for the various types of relays.

B. INDICATING CONTACTOR SWITCH (ICS) – Close the main relay contacts and pass sufficient d-c current through the trip circuit to close the contacts of the ICS. This value of current should not be greater than the particular ICS tap setting being used. The indicator target should drop freely.

C. INDICATING INSTANTANEOUS TRIP UNIT (IIT)

The core screw which is adjustable from the top of the trip unit determines the pickup value. The trip unit has a nominal ratio of adjustment of 1 to 4 and an accuracy within the limits of 10%.

Apply sufficient current to operate the IIT. The indicator target should drop freely.

D. VOLTAGE UNIT (V)

1. Contact Gap – The gap between the stationary contact and moving contact with the relay in a de-energized position should be approximately $.020''$.

2. Sensitivity – The contacts should close when voltage is reduced to approximately 90 volts.

ROUTINE MAINTENANCE

All relays should be inspected periodically and the time of operation should be checked at least once every year or at such other time intervals as may be dictated by experience to be suitable to the particular application. Phantom loads should not be used in testing induction-type relays because of the resulting distorted current wave form which produces an error in timing.

All contacts should be periodically cleaned. A contact burnisher S#182A836H01 is recommended for this purpose. The use of abrasive material for cleaning contacts is not recommended, because of the danger of embedding small particles in the face of the soft silver and thus impairing the contact.

CALIBRATION

Use the following procedure for calibrating the relay if the relay has been taken apart for repairs or the adjustments have been disturbed. This procedure should not be used unless it is apparent that the relay is not in proper working order. (See "Acceptance Check").

A. OVERCURRENT UNIT (CO)

1. Contact

- a) By turning the time dial, move the moving contacts until they deflect the stationary contact to a position where the stationary contact is resting against its backstop. The index mark located on the movement frame should coincide with the "O" mark on the time dial. For double trip relays, the follow on the stationary contacts should be approximately $1/64''$.
- b) For relays identified with a "T", located at lower left of stationary contact block, the index mark on the movement frame will coincide with the "O" mark on the time dial when the stationary contact has moved through approximately one-half of its normal deflection. Therefore, with the stationary contact resting against the backstop, the index mark is offset to the right of the "O" mark by approximately $.020''$. The placement of the various time dial positions in line with the index mark will give operating times as shown on the respective time-current curves. For double trip relays, the follow on the stationary contacts should be approximately $1/32''$.

2. Minimum Trip Current — The adjustment of the spring tension in setting the minimum trip current value of the relay is most conveniently made with the damping magnet removed.

With the time dial set on "0", wind up the spiral spring by means of the spring adjuster until approximately $6-3/4$ convolutions show.

Set the relay on the minimum tap setting, the time dial to position 6.

Adjust the control spring tension so that the moving contact will leave the backstop at tap value current + 1.0% and will return to the backstop at tap value current - 1.0%.

3. Time Curve Calibration - Install the permanent magnet.

Apply the indicated current per Table 1 for the permanent magnet adjustment (e.g. COV-8, 2 times tap value) and measure the operating time. Adjust the permanent magnet keeper until the operating time corresponds to the value of Table 1.

- * For type CO-11 relay only, the 1.30 times tap value operating time from the number 6 time dial position is $54.9 \pm 5\%$ seconds. It is important that the 1.30 times tap value current be maintained accurately. The maintaining of this current accurately is necessary because of the steepness of the slope of the time-current characteristic (Figure 8). A 1% variation in the 1.30 times tap value current (including measuring instrument deviation) will change the nominal operating time by approximately 4%. If the operating time at 1.3 times tap value is not within these limits, a minor adjustment of the control spring will give the correct operating time without any undue effect on the minimum pick-up of the relay. This check is to be made after the 2 times tap value adjustment has been completed.

Apply the indicated current per Table 1 for the electromagnet plug adjustment (e.g. COV-8, 20 times tap value) and measure the operating time. Adjust the proper plug until the operating time corresponds to the value in Table 1. (Withdrawing the left-hand plug, front view, increases the operating time and withdrawing the right-hand plug, front view, decreases the time.) In adjusting the plugs, one plug should be screwed in completely and the other plug run in or out until the proper operating time has been obtained.

Recheck the permanent magnet adjustment. If the operating time for this calibration point has changed, readjust the permanent magnet and then recheck the electromagnet plug adjustment.

B. INDICATING CONTACTOR SWITCH — UNIT (ICS)

Close the main relay contacts and pass sufficient d-c current through the trip circuit to close the contacts of the ICS. This value of current should be not greater than the particular ICS tap setting being used. The indicator target should drop freely.

C. INDICATING INSTANTANEOUS TRIP UNIT (IIT)

The core screw must be adjusted to the value of pick-up current desired.

The nameplate data will furnish the actual current range that may be obtained from IIT unit.

TABLE 1
TIME CURVE CALIBRATION DATA - 50-60 CYCLES FOR
OVERCURRENT UNIT

Relay Type	Time Dial Position	Permanent Magnet Adjustment		Electromagnet Plug Adjustment	
		Current (Multiples of Tap Value)	Operating Time (Seconds)	Current (Multiples of Tap Value)	Operating Time (Seconds)
6	6	2	2.46	20	1.19
7	6	2	4.27	20	1.11
8	6	2	13.35	20	1.11
9	6	2	8.87	20	0.65
11	6	2	11.27	20	0.24 Δ

Δ For 50 cycle COV-11 relay, 20 times operating time limits are 0.24 + 10%, -5%.

D. VOLTAGE UNIT (V)

1. The upper pin bearing should be screwed down until there is approximately .025" clearance between it and the top of shaft bearing. The upper pin bearing should then be securely locked in position with the lock nut. The lower bearing position is fixed and cannot be adjusted.

2. The contact gap adjustment for the directional unit is made as follows:

With the moving contact in the normally-closed position, i.e. against the left stop on bridge, screw in the stationary contact until both contacts just close as indicated by a neon lamp in the contact circuit. Then, screw the stationary contact in towards the moving contact an additional one-half turn. The clamp holding the stationary contact housing need not be loosened for the adjustment since the clamp utilizes a spring-type action in holding the stationary contact in position.

3. The sensitivity adjustment is made in two steps.

A. The adjustable resistor, located at the rear of the voltage unit, is adjusted such that the maximum resistance is in the circuit (Approximately 2500 ohms).


B. The tension of the spiral spring, attached to the moving element assembly, is then varied. The spring is adjusted by placing a screwdriver or similar tool into one of the notches located on the periphery of the spring adjuster and rotating it. The spring adjuster is located on the underside of the bridge and is held in place by a spring type clamp that does not have to be loosened prior to making the necessary adjustments.

The spring is to be adjusted such that the contacts will close as indicated by a neon lamp in the contact circuit when the applied voltage is reduced to 80 volts. The contacts should open with 80 plus volts applied.

Any setting other than the 80 volts then can be made by adjusting the resistor for the desired contact closing voltage.

RENEWAL PARTS

Repair work can be done most satisfactorily at the factory. However, interchangeable parts can be furnished to the customers who are equipped for doing repair work. When ordering parts, always give the complete nameplate data.



57-D-7901

Fig. 11. Outline and Drilling Plan for the Type COV Relay in Type FT21 Case.