

DESIGNATION/RATING:

TYPE:	150 VCP-W 1000, 1200 Amp	3-Pole, 60 Hz
RATED MAXIMUM VOLTAGE:	15 kV	NOMINAL MVA: 1000
RATED SHORT CIRCUIT CURRENT:	37 kA	K-FACTOR: 1.3
RATED INTERRUPTING TIME:	5 Cycles	CONTINUOUS CURRENT: 1200 A

TESTS PERFORMED

All tests were performed to applicable ANSI Standards, and followed procedures of ANSI C37.09 (1979). The applicable industry standards are:

ANSI: C37.04, C37.06, C37.07, C37.09, C37.010, C37.11, C37.20, C37.24, C37.100
NEMA: SG-4, SG-5

[A] Interruption, Close-and-Latch, (Momentary), and Short-Time Tests

Rated Maximum Voltage/Short-Circuit Current	15 kV/ 37kA
(Rated Maximum Voltage/K)/ (K x Short-Circuit Current)	11.5 kV/ 48kA
Close-and-Latch (Momentary) Capability, Asymmetric	77kA
3-Second Short-Time Current Carrying Capability	48kA

Interruption tests were performed in accordance with Table 1 of ANSI C37.09. The following test duties were completed:

1, 2, 3, 4, 5, 6-2, 6-3, 7B-2, 7B-3, 8, 9, 10, 12, 13, 14.
Due to test station limitations, test duty 11 is considered to have been demonstrated by the combination of T.D. 7B-2 and T.D. 12.

[B] BIL/Dielectric Tests

BIL Impulse Test Voltage (1.2/50 micro-sec wave) to ANSI 3 x 3 Test: 95 kV
Rated Power Frequency Withstand Voltage (AC RMS 1 minute): 36 kV
Tests were performed successfully for all 26 terminal test conditions
WHEN INSTALLED IN A WESTINGHOUSE TYPE VC-W SWITCHGEAR VERTICAL SECTION.

[C] Mechanical Endurance Tests

No-load Mechanical Operations:	5,000
Number of Operations Between Servicing:	1,000
Number of Levering Operations:	100

[D] 1200 Ampere Continuous Current Thermal Tests

Maximum hottest spot temperature 105 C; maximum hottest spot temperature rise 65 C, WHEN INSTALLED IN A WESTINGHOUSE TYPE VC-W SWITCHGEAR VERTICAL SECTION.

CERTIFICATION: The above is a true and correct summary of data obtained from tests performed by Westinghouse Electric Corporation. The test results demonstrate the capability of the Type 150 VCP-W 1000, 1200 Ampere circuit breaker to operate properly under normal and short-circuit conditions when applied within its rating.

DATE: August 12, 1987

SIGNED: R. L. Long

DESIGNATION/RATING:

TYPE:	150 VCP-W 1000, 2000 Amp	3-Pole, 60 Hz
RATED MAXIMUM VOLTAGE:	15 kV	NOMINAL MVA: 1000
RATED SHORT CIRCUIT CURRENT:	37 kA	K-FACTOR: 1.3
RATED INTERRUPTING TIME:	5 Cycles	CONTINUOUS CURRENT: 2000 A

TESTS PERFORMED

All tests were performed to applicable ANSI Standards, and followed procedures of ANSI C37.09 (1979). The applicable industry standards are:

ANSI: C37.04, C37.06, C37.07, C37.09, C37.010, C37.11, C37.20, C37.24, C37.100
NEMA: SG-4, SG-5

[A] Interruption, Close-and-Latch, (Momentary), and Short-Time Tests

Rated Maximum Voltage/Short-Circuit Current	15 kV/ 37kA
(Rated Maximum Voltage/K)/ (K x Short-Circuit Current)	11.5 kV/ 48kA
Close-and-Latch (Momentary) Capability, Asymmetric	77kA
3-Second Short-Time Current Carrying Capability	48kA

Interruption tests were performed in accordance with Table 1 of ANSI C37.09. The following test duties were completed:

1, 2, 3, 4, 5, 6-2, 6-3, 7B-2, 7B-3, 8, 9, 10, 12, 13, 14.
Due to test station limitations, test duty 11 is considered to have been demonstrated by the combination of T.D. 7B-2 and T.D. 12.

[B] BIL/Dielectric Tests

BIL Impulse Test Voltage (1.2/50 micro-sec wave) to ANSI 3 x 3 Test: 95 kV
Rated Power Frequency Withstand Voltage (AC RMS 1 minute): 36 kV
Tests were performed successfully for all 26 terminal test conditions
WHEN INSTALLED IN A WESTINGHOUSE TYPE VC-W SWITCHGEAR VERTICAL SECTION.

[C] Mechanical Endurance Tests

No-load Mechanical Operations:	5,000
Number of Operations Between Servicing:	1,000
Number of Levering Operations:	100

[D] 2000 Ampere Continuous Current Thermal Tests

Maximum hottest spot temperature 105 C; maximum hottest spot temperature rise 65 C, WHEN INSTALLED IN A WESTINGHOUSE TYPE VC-W SWITCHGEAR VERTICAL SECTION.

CERTIFICATION: The above is a true and correct summary of data obtained from tests performed by Westinghouse Electric Corporation. The test results demonstrate the capability of the Type 150 VCP-W 1000, 2000 Ampere circuit breaker to operate properly under normal and short-circuit conditions when applied within its rating.

DATE: August 12, 1987

SIGNED: RT Long

DESIGNATION/RATING:

TYPE:	150 VCP-W 1000, 3000 Amp	3-Pole, 60 Hz
RATED MAXIMUM VOLTAGE:	15 kV	NOMINAL MVA: 1000
RATED SHORT CIRCUIT CURRENT:	37 kA	K-FACTOR: 1.3
RATED INTERRUPTING TIME:	5 Cycles	CONTINUOUS CURRENT: 3000 A

TESTS PERFORMED

All tests were performed to applicable ANSI Standards, and followed procedures of ANSI C37.09 (1979). The applicable industry standards are:

ANSI: C37.04, C37.06, C37.07, C37.09, C37.010, C37.11, C37.20, C37.24, C37.100
NEMA: SG-4, SG-5

[A] Interruption, Close-and-Latch, (Momentary), and Short-Time Tests

Rated Maximum Voltage/Short-Circuit Current	15 kV/ 37kA
(Rated Maximum Voltage/K)/ (K x Short-Circuit Current)	11.5 kV/ 48kA
Close-and-Latch (Momentary) Capability, Asymmetric	77kA
3-Second Short-Time Current Carrying Capability	48kA

Interruption tests were performed in accordance with Table 1 of ANSI C37.09. The following test duties were completed:

1, 2, 3, 4, 5, 6-2, 6-3, 7B-2, 7B-3, 8, 9, 10, 12, 13, 14.

Due to test station limitations, test duty 11 is considered to have been demonstrated by the combination of T.D. 7B-2 and T.D. 12.

[B] BIL/Dielectric Tests

BIL Impulse Test Voltage (1.2/50 micro-sec wave) to ANSI 3 x 3 Test: 95 kV
Rated Power Frequency Withstand Voltage (AC RMS 1 minute): 36 kV
Tests were performed successfully for all 26 terminal test conditions
WHEN INSTALLED IN A WESTINGHOUSE TYPE VC-W SWITCHGEAR VERTICAL SECTION.

[C] Mechanical Endurance Tests

No-load Mechanical Operations:	5,000
Number of Operations Between Servicing:	1,000
Number of Levering Operations:	100

[D] 3000 Ampere Continuous Current Thermal Tests

Maximum hottest spot temperature 105 C; maximum hottest spot temperature rise 65 C, WHEN INSTALLED IN A WESTINGHOUSE TYPE VC-W SWITCHGEAR VERTICAL SECTION.

CERTIFICATION: The above is a true and correct summary of data obtained from tests performed by Westinghouse Electric Corporation. The test results demonstrate the capability of the Type 150 VCP-W 1000, 3000 Ampere circuit breaker to operate properly under normal and short-circuit conditions when applied within its rating.

DATE: August 12, 1987

SIGNED: Robert Long