



Type BAL-1 Current Limiting (Non-Indicating) Fuse
Melting time-current characteristics, 600 VDC

Curves are based on tests starting with fuse units at an ambient temperature of 25°C and without initial load. Curves are plotted to minimum test points so variations should be positive.

Westinghouse Electric Corporation
Switchgear Division, Power Switching Equipment, East Pittsburgh, Pa.
Printed in USA

Curve No.

51

New Information

Reference No. 424792-A

May, 1968