

## GENERAL

Type 221 instruments are designed and built to meet or exceed the requirements of American Standard C39.1 for electrical indicating switchboard instruments. The rated accuracy class is one per cent.

#### CASES

The first letter in the Type designation indicates the form of case used.

K=Rectangular Flush Case, Flange mounted.

#### MECHANISMS

The second letter in the type designation indicates the principle of operation.

> X=Permanent magnet moving coil A=Repulsion, moving iron Y=Electrodynamic C=Rectifier plus X

## DESCRIPTION OF TAUT BAND SUSPENSION IN-STRUMENTS

CAUTION: When the instrument mechanism is exposed, avoid contact with the tension springs. These springs are precisely made and positioned, and any pressures inadvertently applied to them may cause misalignment of the moving element.

The X-221 is a pivotless, bearingless d.c. instrument of the permanent magnet moving coil type. A suspension system is employed which replaces the conventional pivots, jewels, and control spring. At each end of the moving coil is attached a thin metallic band. At the front and rear bridges these bands are connected to tension springs. The tension springs exert axial forces which keep the metallic bands taut and the moving element from sagging. The taut bands serve to carry current to the moving coil, and also provide the necessary deflection countertorque.

The A-221 Ammeters and Voltmeters employ

SUPERSEDES I.L. 43-221C \*Denotes Change from Superseded Issue. similar suspensions but operate on the repulsion, moving iron principle.

The taut band design eliminates pivot friction and allows the instrument to withstand severe conditions of shock and vibration. The suspension system assures longer life with reduced maintenance costs.

The Y221 wattmeters and power factor meters are the Electrodynamic pivot and jewel type.

# DIAL NOTES

References to type style number, use of external components if required, coil ratings, calibration data etc., are made on the dial.

### INSTALLATION

Unpack instruments carefully. Terminal and mounting hardware, and any external components may be in separate packages.

Drill panels and connect instruments according to the diagrams in this leaflet, or according to switchboard drawings if instruments are supplied as part of a switchboard.

Before energizing the instrument, adjust the pointer to zero by means of the zero adjuster at the front of the instrument.

## CIRCUIT PRECAUTIONS

#### HIGH VOLTAGE OPERATION

All instruments are insulated for 800 volt maximum service.

When voltmeters are used with external resistors on voltages higher than the insulation rating of the instrument, one terminal of the instrument should be grounded.

Ammeters with external shunts must be used with leads having the resistance specified in the dial notes. If the circuit voltage exceeds the insulation

**EFFECTIVE MAY 1966** 

rating of the instrument, the shunt should be in the grounded side of the line.

#### GROUNDING OF CASES

Instruments, when mounted on grounded metal structures, are considered adequately grounded when secured to the structures by metal hardware. For mounting on insulated structures any one of the three case to base mounting screws may be used as a grounding terminal.

## REPAIRS AND RENEWAL PARTS

The usual procedures and practices employed for servicing mechanisms of pivot-jewel type instruments cannot be applied to suspension type instruments. For this reason we recommend that all TBS instruments in need of mechanism servicing be returned to the factory.

Orders for renewal parts should include the name of the part and the style and serial number of the instrument, appearing on the dial.



Fig. 1. Outline Dimensions and Drilling Plan for Type K-221 Instruments.





Fig. 3. Outline Dimensions and Drilling Plan for VR-825 External Resistor.



-

Fig. 4. Outline Dimensions and Drilling Plan for Phase Shifting Transformer used with 3-phase, 3-wire, and 3-phase 4-wire, Varmeter.

former.



former.

I.L. 43-221D

Potential Transformer.

# K-221 LINE SWITCHBOARD INSTRUMENTS



Fig. 14. Types Y-221 Polyphase 3 current coil wattmeter with Current Transformer and Potential Transformer.



Fig. 17. Types Y-221 Single Phase Varmeter with C.T. and P.T.



Fig. 15. Types Y-221 Polyphase 2 Current Coil Varmeter with Current Transformer and Potential Transformer.



Fig. 16. Types Y-221 Polyphase 3 Current Coil Varmeter with Current Transformer and Potential Transformer.

REAR VIEW





Fig. 18. Type KY-221 Single Phase Power Factor Meter With External Reactor.

Fig. 19. Type KY-221 3-Phase 3-Wire Power Factor Meter.



Fig. 20 Type KY-221 3-Phase 4-Wire Power Factor Meter External Wiring

WESTINGHOUSE ELECTRIC CORPORATION RELAY-INSTRUMENT DIVISION NEWARK, N. J.

Printed in U.S.A.



# GENERAL

Type 221 instruments are designed and built to meet or exceed the requirements of American Standard C39.1 for electrical indicating switchboard instruments. The rated accuracy class is one per cent.

#### CASES

The first letter in the Type designation indicates the form of case used.

K=Rectangular Flush Case, Flange mounted.

#### MECHANISMS

The second letter in the type designation indicates the principle of operation.

X=Permanent magnet moving coil

A=Repulsion, moving iron

Y=Electrodynamic

C=Rectifier plus X

### DESCRIPTION OF TAUT BAND SUSPENSION IN-STRUMENTS

CAUTION: When the instrument mechanism is exposed, avoid contact with the tension springs. These springs are precisely made and positioned, and any pressures inadvertently applied to them may cause misalignment of the moving element.

The X-221 is a pivotless, bearingless d.c. instrument of the permanent magnet moving coil type. A suspension system is employed which replaces the conventional pivots, jewels, and control spring. At each end of the moving coil is attached a thin metallic band. At the front and rear bridges these bands are connected to tension springs. The tension springs exert axial forces which keep the metallic bands taut and the moving element from sagging. The taut bands serve to carry current to the moving coil, and also provide the necessary deflection countertorque.

The A-221 Ammeters and Voltmeters employ similar suspensions but operate on the repulsion, moving iron principle. The taut band design eliminates pivot friction and allows the instrument to withstand severe conditions of shock and vibration. The suspension system assures longer life with reduced maintenance costs.

The Y221 wattmeters and power factor meters are the Electrodynamic pivot and jewel type.

## DIAL NOTES

References to type style number, use of external components if required, coil ratings, calibration data etc., are made on the dial.

# INSTALLATION

Unpack instruments carefully. Terminal and mounting hardware, and any external components may be in separate packages.

Drill panels and connect instruments according to the diagrams in this leaflet, or according to switchboard drawings if instruments are supplied as part of a switchboard.

Before energizing the instrument, adjust the pointer to zero by means of the zero adjuster at the front of the instrument.

# CIRCUIT PRECAUTIONS

\* CAUTION: Dial and pointer may be at dangerous voltage levels when instrument is energized.

#### HIGH VOLTAGE OPERATION

All instruments are insulated for 800 volt maximum service.

When voltmeters are used with external resistors on voltages higher than the insulation rating of the instrument, one terminal of the instrument should be grounded.

Ammeters with external shunts must be used with leads having the resistance specified in the dial notes. If the circuit voltage exceeds the insulation

These instructions neither cover all details or variations in equipment nor provide for all contingencies with regard to installation, operation or maintenance. On request, Westinghouse will be glad to supply further information as to particular problems or questions which are not covered sufficiently for the purchaser's needs.

SUPERSEDES I.L. 43-221F \*Denotes Change from Superseded Issue. rating of the instrument, the shunt should be in the grounded side of the line.

#### GROUNDING OF CASES

Instruments, when mounted on grounded metal structures, are considered adequately grounded when secured to the structures by metal hardware. For mounting on insulated structures any one of the three case to base mounting screws may be used as a grounding terminal.

## REPAIRS AND RENEWAL PARTS

Repair work can be done most satisfactorily at the factory, or at any authorized Instrument Repair Facility (see Service Directory 43-000). However, interchangeable parts can be furnished to the customers who are equipped for doing repair work. When ordering parts always give complete nameplate data.







P.C.



### K-221 LINE SWITCHBOARD INSTRUMENTS \_



WESTINGHOUSE ELECTRIC CORPORATION RELAY-INSTRUMENT DIVISION NEWARK, N. J.

#### Printed in U.S.A.