

DESIGNATION/RATINGS: TYPE 75 VCP-W 500	Continuous Current:	2000 A
Maximum Voltage: 8.25 kV	Short Circuit Current:	33 kA
60 Hz 1 min Withstand: 36 kV	Short Time (2 s) Current:	41 kA
Impulse Withstand: 95 kV	Momentary Current Crest:	111 kA
Voltage Range Factor K: 1.25	(RMS Total Current):	66 kA
MVA: 500		

TESTS PERFORMED

All tests were performed to applicable ANSI Standards, and followed procedures of ANSI C37.09 (1979), and C37.20.2 (1987). The applicable standards are: ANSI:C37.04, C37.06, C37.07, C37.09, C37.010, C37.11, C37.20.2, C37.24, C37.100 NEMA: SG-4, SG-5

[A] Momentary and Short-Time Tests

Rated Maximum Voltage / Short-Circuit Current	8.25 kV / 33 kA
(Rated Maximum Voltage/K) / (K x Short-Circuit Current)	6.6 kV / 41 kA
Momentary Current Capability (kA Crest / kA RMS Asymmetric)	111 kA / 66 kA
Short-Time (2 second) Current Carrying Capability (kA RMS symmetric)	41 kA

Momentary current tests were performed in accordance with Section 5.2.4 of ANSI C37.20.2. The Type VacClad-W switchgear withstood a three phase momentary current averaging more than 41 kA RMS symmetric, with a crest value of more than 111 kA (total current more than 66 kA RMS asymmetric) for more than 10 cycles (167 ms). The Type VacClad-W switchgear also carried a three phase current averaging more than 41 kA RMS symmetric for more than two seconds.

[B] BIL/Dielectric Tests

BIL Impulse Test Voltage (1.2/50 micro-sec wave) to ANSI 3 x 3 Test:	95 kV
Rated Power Frequency (60 Hz) Withstand Voltage (ac RMS 1 minute):	36 kV

Tests were performed successfully for all 26 terminal test conditions.

[C] Mechanical Endurance Tests

Number of Levering Operations:	100
No-load Mechanical Operations (of circuit breaker):	10,000
Number of Operations Between Servicing:	2,000

[D] Continuous Current Thermal Tests

With 2000 Amperes 60 Hz ac current flowing, the maximum hot spot temperature is less than 105 C. The maximum hot spot temperature rise is less than 65 C.

CERTIFICATION:

The above is a true and correct summary of data obtained from tests performed by Westinghouse Electric Corporation. The test results demonstrate the capability of the 2000 Ampere, Type 75 VacClad-W 500 switchgear to operate properly under normal and short-circuit conditions when applied within its rating.

THIS CERTIFICATE IS VALID for a 2000 A, Westinghouse Type VAC-CLAD-W Switchgear Vertical Section with A 2000 A, Type 75 VCP-W 500 Circuit Breaker.

DATE: March 21, 1989

SIGNED: 

DESIGNATION/RATINGS: TYPE 75 VCP-W 500	Continuous Current: 3000 A
Maximum Voltage: 8.25 kV	Short Circuit Current: 33 kA
60 Hz 1 min Withstand: 36 kV	Short Time (2 s) Current: 41 kA
Impulse Withstand: 95 kV	Momentary Current Crest: 111 kA
Voltage Range Factor K: 1.25	(RMS Total Current): 66 kA
MVA: 500	

TESTS PERFORMED

All tests were performed to applicable ANSI Standards, and followed procedures of ANSI C37.09 (1979), and C37.20.2 (1987). The applicable standards are: ANSI:C37.04, C37.06, C37.07, C37.09, C37.010, C37.11, C37.20.2, C37.24, C37.100
NEMA: SG-4, SG-5

[A] Momentary and Short-Time Tests

Rated Maximum Voltage / Short-Circuit Current	8.25 kV / 33 kA
(Rated Maximum Voltage/K) / (K x Short-Circuit Current)	6.6 kV / 41 kA
Momentary Current Capability (kA Crest / kA RMS Asymmetric)	111 kA / 66 kA
Short-Time (2 second) Current Carrying Capability (kA RMS symmetric)	41 kA

Momentary current tests were performed in accordance with Section 5.2.4 of ANSI C37.20.2. The Type VacClad-W switchgear withstood a three phase momentary current averaging more than 41 kA RMS symmetric, with a crest value of more than 111 kA (total current more than 66 kA RMS asymmetric) for more than 10 cycles (167 ms). The Type VacClad-W switchgear also carried a three phase current averaging more than 41 kA RMS symmetric for more than two seconds.

[B] BIL/Dielectric Tests

BIL Impulse Test Voltage (1.2/50 micro-sec wave) to ANSI 3 x 3 Test:	95 kV
Rated Power Frequency (60 Hz) Withstand Voltage (ac RMS 1 minute):	36 kV

Tests were performed successfully for all 26 terminal test conditions.

[C] Mechanical Endurance Tests

Number of Levering Operations:	100
No-load Mechanical Operations (of circuit breaker):	5,000
Number of Operations Between Servicing:	1,000

[D] Continuous Current Thermal Tests

With 3000 Amperes 60 Hz ac current flowing, the maximum hot spot temperature is less than 105 C. The maximum hot spot temperature rise is less than 65 C.

CERTIFICATION:

The above is a true and correct summary of data obtained from tests performed by Westinghouse Electric Corporation. The test results demonstrate the capability of the 3000 Ampere, Type 75 VacClad-W 500 switchgear to operate properly under normal and short-circuit conditions when applied within its rating.

THIS CERTIFICATE IS VALID for a 3000 A, Westinghouse Type VAC-CLAD-W Switchgear Vertical Section with A 3000 A, Type 75 VCP-W 500 Circuit Breaker.

DATE: March 21, 1989

SIGNED: *P. H. Long*